

【施設維持管理情報 平成31年】

3月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	175	175	175	1,000	1,000	1,000	2.0	2.1	1.7
2 土	175	175	175	1,000	1,000	1,001	1.7	1.2	1.8
3 日		174	175		1,000	1,000		2.0	1.7
4 月	174	177	175	1,001	1,002	1,000	2.1	2.2	1.9
5 火	172	179	175	1,000	1,000	1,002	2.1	2.0	2.2
6 水	175	170	175	1,000	1,000	1,000	1.7	2.3	2.9
7 木	175	175	175	1,000	1,000	1,000	3.0	2.7	1.2
8 金	175	175	175	1,000	1,000	1,000	2.2	2.3	1.9
9 土	177	175	176	1,001	1,000	1,002	1.9	2.0	2.0
10 日		175	175		1,000	1,000		2.5	2.4
11 月	175	175	175	1,000	1,000	1,000	2.0	2.3	2.5
12 火	175	175	177	1,000	1,000	1,000	2.2	2.4	2.5
13 水	175	175	177	1,000	1,000	1,000	1.7	2.0	1.2
14 木	175	175	175	1,000	1,002	1,002	2.0	2.1	2.3
15 金	175	172	173	1,000	1,000	1,000	1.2	1.3	1.6
16 土	175	175	175	1,000	1,000	1,000	2.0	2.2	2.4
17 日	175	175		1,000	1,000		2.5	3.0	
18 月			175			1,000			2.0
19 火	175	175	175	1,000	1,000	1,000	2.2	3.2	3.2
20 水	175	175	175	1,000	1,000	1,000	2.1	2.1	1.7
21 祝	175	175		1,000	1,000		2.0	1.9	
22 金	175	175	175	1,000	1,000	1,000	2.0	1.5	2.0
23 土	175	175	175	1,000	1,000	1,000	1.7	1.8	2.1
24 日	175	175	175	1,000	1,001	1,001	2.1	1.9	1.6
25 月	175	177	170	1,000	1,000	1,000	2.2	2.5	1.9
26 火	170	172	175	1,000	1,000	1,002	2.1	2.2	2.5
27 水	175	175	175	1,000	1,000	1,002	1.7	2.0	1.8
28 木	175	175	175	1,000	1,002	1,000	2.0	2.5	1.2
29 金	175	172	174	1,000	1,001	1,001	2.1	1.7	1.9
30 土	175	175	173	1,000	1,000	1,000	1.9	2.5	3.0
31 日									