

【施設維持管理情報 平成31年】

4月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	175	175	1,000	1,000	1,000	2.0	2.1	2.5
2 火	175	175	175	1,000	1,000	1,000	1.5	1.9	2.0
3 水	175	175	175	1,000	1,000	1,000	1.2	2.2	1.9
4 木	175	175	177	1,000	1,001	1,002	2.0	2.0	1.7
5 金	175	174	175	1,000	1,000	1,001	3.2	2.2	2.5
6 土	175		170	1,000	1,000	1,000	1.2	1.7	1.9
7 日		175	175			1,000			2.5
8 月		175	175		1,000	1,000		2.0	1.9
9 火		175	172		1,002	1,001		2.2	2.5
10 水	175	177	175	1,000	1,000	1,002	1.7	1.7	2.0
11 木	175	170	172	1,000	1,000	1,000	2.2	2.0	2.3
12 金	175	175	175	1,000	1,001	1,001	1.9	2.9	3.2
13 土	175	175	175	1,000	1,000	1,002	2.0	2.2	2.5
14 日	175	175		1,000	1,000		2.2	2.2	
15 月	175	172	176	1,001	1,003	1,000	1.7	2.0	2.7
16 火	175	170		1,000	1,001		1.9	1.8	
17 水	175	175	170	1,001	1,000	1,000	2.2	2.1	3.0
18 木	175	175	175	1,000	1,000	1,001	2.0	2.2	3.2
19 金	175	172	175	1,000	1,001	1,000	1.7	1.7	1.8
20 土	175	175	175	1,000	1,000	1,000	2.1	2.2	2.5
21 日	175	175	177	1,001	1,001	1,003	1.8	1.8	2.2
22 月	175	175	175	1,000	1,000	1,000	2.0	2.1	2.0
23 火	175	175	175	1,000	1,000	1,001	2.0	1.9	2.2
24 水		175	175		1,000	1,000		2.0	2.1
25 木	175	175	175	1,000	1,000	1,001	3.2	2.2	2.1
26 金	175	179	179	1,001	1,001	1,002	2.1	2.0	1.9
27 土									
28 日									
29 祝									
30 祝									