

【施設維持管理情報 令和元年】

6月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土	175	175	175	1,000	1,000	1,001	2.2	2.1	2.3
2 日		175	175		1,000	1,000		2.0	3.0
3 月	175	175		1,000	1,001		2.2	2.1	
4 火	175	175		1,000	1,001		2.0	2.1	
5 水	175	177	175	1,001	1,000	1,000	2.0	2.2	2.4
6 木	175	175	170	1,000	1,000	1,000	1.7	2.0	2.0
7 金		175	172		1,000	1,000		3.2	4.2
8 土	173	172	175	1,000	1,001	1,001	2.2	2.5	3.5
9 日	175	175		1,000	1,000		2.2	2.9	
10 月	175	175	177	1,000	1,001	1,000	2.5	2.9	3.3
11 火	175	179	170	1,000	1,000	1,000	2.1	3.2	2.2
12 水	175	173	173	1,000	1,000	1,000	2.1	2.1	2.0
13 木	175	175	175	1,000	1,000	1,000	3.2	3.2	3.5
14 金	175	175	175	1,001	1,002	1,001	2.7	2.1	2.0
15 土	175	175	175	1,000	1,000	1,000	3.2	3.4	2.2
16 日		175	175		1,000	1,000		2.5	2.7
17 月		175	175		1,000	1,000		2.1	3.2
18 火	175	175	175	1,000	1,000	1,000	3.2	3.5	2.7
19 水	175	175	175	1,000	1,000	1,000	2.0	2.1	2.1
20 木	175	179	170	1,000	1,000	1,000	2.1	2.0	3.2
21 金	175	175	172	1,000	1,002	1,002	3.2	3.5	3.7
22 土	175	175	177	1,001	1,001	1,001	2.2	2.5	2.4
23 日	175	175	175	1,000	1,000	1,001	3.2	2.9	3.2
24 月	175	174	175	1,000	1,000	1,000	3.2	2.0	2.1
25 火	175	175	174	1,000	1,001	1,003	2.2	2.1	3.1
26 水	175	170	170	1,000	1,000	1,000	3.2	3.3	2.2
27 木	175	175	175	1,000	1,000	1,000	2.1	2.3	2.1
28 金	175	175	174	1,000	1,001	1,000	2.4	2.6	3.2
29 土	175	175	175	1,000	1,000	1,000	2.1	2.5	2.7
30 日		175	175		1,000	1,002		3.2	3.5