

【施設維持管理情報 令和元年】

7月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	175	175	1,001	1,000	1,001	1.2	1.7	0.5
2 火	175	175	175	1,000	1,000	1,002	0.2	2.0	0.7
3 水	175	175	174	1,000	1,000	1,000	1.2	2.0	2.1
4 木	175	177	170	1,000	1,000	1,000	1.7	0.9	0.7
5 金	177	170	172	1,000	1,000	1,002	1.2	2.0	1.3
6 土	172	173	175	1,000	1,000	1,000	1.0	1.1	1.0
7 日	175	175		1,000	1,001		1.2	2.0	
8 月	170	174	173	1,000	1,001	1,001	1.3	1.0	1.2
9 火	170	175	175	1,002	1,000	1,000	1.0	1.2	0.9
10 水	175	170	175	1,000	1,000	1,000	2.1	1.2	1.5
11 木	170	175	175	1,000	1,000	1,000	0.9	0.7	1.2
12 金	170	175	174	1,000	1,001	1,001	1.2	1.3	0.9
13 土	175	175	175	1,000	1,000	1,000	1.7	2.0	1.2
14 日	175	175	176	1,000	1,000	1,000	1.2	1.3	1.3
15 祝	175	175	175	1,000	1,001	1,001	2.0	1.3	1.7
16 火									
17 水									
18 木	175	175	172	1,000	1,000	1,000	1.9	2.1	2.3
19 金	175	175	175	1,000	1,000	1,000	2.0	2.1	2.0
20 土		175	175		1,000	1,000		2.1	1.3
21 日	175	175		1,000	1,000		2.1	0.9	
22 月	175	175	175	1,000	1,000	1,000	2.0	1.3	0.2
23 火	175	175		1,000	1,000		1.7	1.5	
24 水	175	175		1,000	1,000		1.0	1.2	
25 木		175	175		1,000	1,000		2.0	1.7
26 金	175	175	175	1,000	1,000	1,001	2.1	2.3	0.9
27 土	175	175	175	1,000	1,000	1,000	1.2	1.2	0.7
28 日	170	174	175	1,002	1,002	1,000	0.3	0.5	0.7
29 月	175	172		1,001	1,000		1.2	1.0	
30 火	175	175	175	1,000	1,000	1,000	2.0	1.7	2.0
31 水	175	175	175	1,000	1,000	1,000	0.9	1.2	0.5