

【施設維持管理情報 令和元年】

8月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	175	172	170	1,000	1,000	1,000	1.2	1.3	1.0
2 金	175	175	170	1,000	1,002	1,001	1.0	1.1	1.1
3 土	175	175	172	1,000	1,000	1,001	2.1	2.0	1.7
4 日	175	175	172	1,000	1,002	1,000	2.1	1.7	1.5
5 月	175	175	175	1,000	1,001	1,000	2.3	1.5	1.0
6 火	175	175	175	1,000	1,002	1,000	1.2	1.0	0.9
7 水	175	175	175	1,000	1,001	1,000	1.2	1.3	1.1
8 木	175	175	170	1,002	1,002	1,003	1.7	1.5	1.5
9 金	173	175	172	1,000	1,000	1,001	2.1	2.0	1.5
10 土	175	175	170	1,000	1,001	1,002	2.0	1.7	1.8
11 祝	175	170	173	1,000	1,000	1,000	1.8	1.9	1.5
12 振									
13 火									
14 水									
15 木									
16 金									
17 土									
18 日			175			1,000			2.0
19 月									
20 火									
21 水	175	175	175	1,001	1,001	1,001	2.1	2.1	2.0
22 木	175	175	175	1,000	1,000	1,000	1.7	1.7	2.1
23 金	175	175	172	1,000	1,000	1,000	2.0	1.9	1.9
24 土	175	170	177	1,001	1,002	1,002	1.5	1.5	1.3
25 日	175	172	173	1,000	1,001	1,000	1.9	1.8	1.3
26 月	177	173	175	1,000	1,000	1,000	1.5	1.3	1.2
27 火	175	175	177	1,000	1,000	1,001	2.0	2.1	2.0
28 水	170	172	175	1,000	1,001	1,001	2.0	1.7	1.5
29 木	175	175	175	1,000	1,001	1,000	2.1	1.3	1.9
30 金	175	172	175	1,001	1,002	1,002	1.9	1.9	1.7
31 土	175	172	175	1,000	1,000	1,000	1.7	2.0	2.1