

【施設維持管理情報 令和元年】

9月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	175	175	1,000	1,000	1,000	1.5	1.9	2.0
2 月	175	175	175	1,000	1,001	1,000	2.0	2.2	1.9
3 火	175	175	175	1,000	1,000	1,001	2.1	2.1	1.7
4 水	175	175	174	1,000	1,000	1,000	2.2	2.5	1.9
5 木	175	175	174	1,000	1,000	1,000	1.7	1.8	1.7
6 金	173	170	175	1,001	1,000	1,000	2.2	2.2	2.0
7 土	175	175	170	1,000	1,000	1,000	2.0	2.5	1.9
8 日	175	175	175	1,000	1,000	1,000	1.2	1.5	2.0
9 月	175	175		1,000	1,000		2.0	2.2	
10 火	175	175	175	1,000	1,000	1,000	1.5	2.0	1.7
11 水	175	175	175	1,000	1,000	1,000	2.0	2.1	2.0
12 木	175	175	177	1,000	1,000	1,000	1.7	1.5	1.5
13 金	175	175	175	1,000	1,000	1,000	2.5	2.7	2.0
14 土	175	175	175	1,000	1,000	1,000	2.1	2.0	2.0
15 日	175	175	170	1,000	1,000	1,000	1.5	1.9	2.0
16 祝	175	175	175	1,001	1,001	1,002	2.2	2.0	1.7
17 火	175	175	175	1,000	1,001	1,000	1.9	1.5	2.0
18 水		175	175		1,000	1,000		2.2	2.1
19 木	175	175	175	1,000	1,000	1,000	2.0	2.1	1.7
20 金		175	175		1,000	1,000		2.2	2.1
21 土	175	175	170	1,000	1,000	1,000	2.2	2.5	2.1
22 日	175	175	177	1,001	1,000	1,001	2.5	2.9	1.7
23 祝	175	175	175	1,000	1,000	1,000	1.9	1.7	2.0
24 火	175	175	175	1,000	1,000	1,000	2.0	2.1	2.0
25 水	175	175	175	1,000	1,000	1,001	2.2	1.7	1.7
26 木	175	175	175	1,000	1,002	1,002	2.2	2.1	2.5
27 金	175	175	175	1,001	1,000	1,000	1.9	2.0	2.3
28 土	175	175	175	1,000	1,001	1,000	2.7	3.2	3.0
29 日			175			1,000			2.5
30 月	175	175	174	1,000	1,000	1,000	2.1	2.1	2.0