

【施設維持管理情報 令和2年】

1月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 木									
3 金									
4 土									
5 日									
6 月	175	175	175	1,000	1,001	1,000	2.3	2.5	3.0
7 火	175	177	174	1,000	1,000	1,000	2.0	3.2	3.2
8 水	174	170	175	1,000	1,000	1,000	2.1	2.9	3.3
9 木	175	174	175	1,000	1,000	1,001	2.3	2.2	2.3
10 金	170	172	175	1,000	1,002	1,000	2.5	2.1	2.3
11 土	175	175	172	1,000	1,000	1,000	2.2	3.0	2.7
12 日	175	175	175	1,000	1,000	1,000	2.3	2.5	2.0
13 祝	175	175	175	1,001	1,000	1,000	3.2	2.7	2.7
14 火	172	172	173	1,000	1,000	1,001	2.3	2.4	1.9
15 水	175	175	173	1,000	1,000	1,000	2.0	2.1	2.2
16 木	175	175	175	1,000	1,000	1,000	2.1	2.3	2.9
17 金	175	175	175	1,000	1,000	1,001	2.1	2.0	2.3
18 土	175	175	175	1,000	1,000	1,000	2.1	2.5	2.7
19 日	175	172	172	1,000	1,001	1,001	3.2	3.0	2.1
20 月	175	173	175	1,000	1,000	1,002	3.0	2.7	2.5
21 火	175	175	174	1,000	1,000	1,000	2.7	2.5	2.9
22 水	174	173	175	1,000	1,000	1,000	3.2	3.5	3.2
23 木	175	175	175	1,000	1,000	1,001	2.7	2.5	2.5
24 金	175	175	174	1,002	1,002	1,000	3.2	3.3	3.3
25 土	175	175	175	1,000	1,001	1,001	2.7	2.4	2.5
26 日	175	175	175	1,000	1,000	1,000	2.3	2.0	2.7
27 月	175	175	175	1,000	1,002	1,000	3.2	3.0	2.3
28 火	175	173	170	1,000	1,000	1,000	2.5	2.4	2.4
29 水	175	173	173	1,000	1,000	1,000	2.1	2.3	3.0
30 木	175	175	175	1,000	1,000	1,000	2.1	2.5	2.7
31 金	175	175	175	1,000	1,001	1,000	3.0	2.9	3.0