

【施設維持管理情報 令和2年】

3月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度 (PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	174	175	1,000	1,001	1,001	2.5	2.9	3.4
2 月	174	175	170	1,000	1,000	1,000	2.7	2.5	3.7
3 火	175	175	175	1,000	1,000	1,001	3.2	2.7	2.7
4 水	175	172	175	1,000	1,000	1,002	3.0	2.5	2.5
5 木	175	175	175	1,000	1,000	1,002	3.2	3.5	2.2
6 金	172	175	173	1,001	1,001	1,002	3.7	2.9	3.2
7 土	175	174	173	1,000	1,000	1,000	2.9	2.5	3.0
8 日	175	175	175	1,000	1,000	1,000	3.2	3.4	3.7
9 月	175	177	176	1,000	1,000	1,002	2.2	2.5	2.9
10 火	175	175	174	1,000	1,001	1,000	3.0	3.2	3.5
11 水	175	175	175	1,000	1,000	1,000	3.2	2.9	2.5
12 水木	174	175	175	1,001	1,001	1,002	2.0	2.2	2.7
13 金	175	177	175	1,000	1,000	1,001	3.0	3.2	3.3
14 土	175	175	175	1,000	1,000	1,000	2.5	2.1	2.3
15 日	175	175	175	1,000	1,000	1,000	2.2	2.5	3.2
16 月	175	175	174	1,000	1,001	1,001	3.2	3.5	3.4
17 火	175	170	172	1,000	1,000	1,000	3.5	3.7	3.2
18 水	175	175	172	1,000	1,000	1,000	3.2	3.7	2.9
19 木	175	175	175	1,000	1,000	1,000	2.9	2.9	3.2
20 祝		175	175		1,001	1,001		3.1	2.7
21 土	175	174	173	1,000	1,002	1,001	3.0	3.2	3.9
22 日	175	175		1,000	1,000		2.5	2.7	
23 月	175	172	173	1,000	1,000	1,000	2.9	3.2	2.9
24 火	175	175	173	1,000	1,000	1,001	3.2	3.2	3.2
25 水	175	174	170	1,000	1,000	1,000	3.9	2.9	2.7
26 木	175	175	175	1,000	1,001	1,001	2.9	2.5	2.5
27 金	175	175	170	1,000	1,001	1,000	3.5	3.7	3.8
28 土	175	175	175	1,000	1,000	1,000	4.2	3.2	3.7
29 日	175	175	175	1,000	1,000	1,000	2.9	2.7	3.0
30 月	175	175	174	1,001	1,001	1,002	2.7	3.2	3.2
31 火	175	175	175	1,000	1,000	1,000	2.1	2.3	2.7

