

【施設維持管理情報 令和2年】

4月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	173	175	1,000	1,000	1,000	3.2	3.5	3.0
2 木	175	175	175	1,000	1,000	1,000	2.0	2.1	2.5
3 金	175	174	175	1,000	1,001	1,000	2.2	2.4	3.2
4 土	175	175	176	1,000	1,000	1,000	2.0	1.7	2.0
5 日	175	175	175	1,000	1,000	1,000	2.1	2.1	2.0
6 月	175	175	175	1,000	1,001	1,000	2.9	2.7	2.1
7 火	175	175	175	1,000	1,000	1,000	2.0	1.7	1.9
8 水	175	175	174	1,000	1,000	1,000	2.1	2.5	2.7
9 木	175	175	174	1,000	1,001	1,000	2.0	1.9	1.7
10 金	175	175	175	1,000	1,000	1,000	2.2	2.3	1.9
11 土	175	175	175	1,000	1,000	1,000	1.7	1.2	1.5
12 日									
13 月	175	175	175	1,001	1,001	1,000	2.0	1.7	2.3
14 火	175	175	175	1,000	1,000	1,000	2.1	2.2	2.5
15 水	175	175	175	1,000	1,000	1,000	2.1	1.7	1.9
16 木	175	175	172	1,001	1,002	1,002	1.3	1.7	1.5
17 金	175	174	175	1,000	1,000	1,000	1.2	1.2	1.9
18 土	175	175	175	1,000	1,000	1,000	2.1	2.5	2.0
19 日	175	175		1,000	1,001		2.3	2.1	
20 月	175	175	170	1,000	1,000	1,000	1.7	2.1	3.0
21 火	175	175	172	1,002	1,001	1,000	2.2	2.5	2.5
22 水	175	175	174	1,000	1,001	1,001	2.5	1.7	1.9
23 木	175	173	170	1,000	1,000	1,000	3.0	2.7	2.2
24 金	175	175	172	1,000	1,000	1,001	1.2	1.4	1.7
25 土	170	172	170	1,000	1,000	1,002	1.2	1.5	1.9
26 日	175	175		1,000	1,000		2.0	1.7	
27 月	175	174	175	1,000	1,000	1,000	2.1	2.0	1.3
28 火	175	175	174	1,000	1,000	1,000	2.1	2.4	1.7
29 祝		175	175		1,001	1,000		1.7	1.5
30 木	175	175	174	1,000	1,000	1,001	2.0	2.1	1.2