

【施設維持管理情報 令和2年】

7月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	175	175	1,000	1,000	1,000	1.5	2.0	1.7
2 木	175	175	174	1,001	1,000	1,000	2.0	2.1	2.1
3 金	175	175	174	1,000	1,000	1,000	1.5	1.2	1.2
4 土	175	175	175	1,000	1,000	1,000	1.2	1.0	1.2
5 日	175	174	175	1,000	1,000	1,000	1.7	1.5	2.2
6 月	175	175	170	1,000	1,001	1,000	1.8	2.0	2.5
7 火			175			1,000			2.5
8 水	175	175	175	1,000	1,000	1,000	2.0	2.1	1.9
9 木	175	175	170	1,000	1,001	1,000	1.7	1.9	2.0
10 金	175	175	175	1,000	1,000	1,000	1.2	1.0	1.5
11 土	175	172	173	1,001	1,002	1,000	1.0	0.5	1.0
12 日	175	175	174	1,000	1,000	1,001	1.2	1.3	1.0
13 月	172	175	174	1,000	1,000	1,001	1.5	1.3	1.7
14 火	175	175	173	1,001	1,002	1,002	1.9	1.5	2.0
15 水	175	175	175	1,000	1,000	1,000	2.0	2.1	2.0
16 木	175	175	174	1,000	1,002	1,000	1.7	1.6	1.2
17 金	175	175	174	1,000	1,000	1,000	2.0	2.1	2.3
18 土	175	175	174	1,000	1,000	1,000	1.9	1.7	2.0
19 日	175	174	170	1,000	1,001	1,000	2.0	1.7	1.5
20 月	175	175	172	1,000	1,000	1,000	2.1	2.0	1.7
21 火	175	175	174	1,000	1,000	1,000	2.0	1.5	1.7
22 水	175	175	175	1,000	1,000	1,000	1.5	1.6	1.2
23 祝	175	173	175	1,000	1,000	1,000	2.0	1.7	1.9
24 祝	175	175	175	1,000	1,000	1,000	1.7	1.5	2.0
25 土	175	172	174	1,000	1,000	1,000	1.0	1.7	1.7
26 日									
27 月									
28 火									
29 水			175			1,000			2.0
30 木	175	175	174	1,000	1,000	1,000	2.1	1.7	1.4
31 金	175	175	174	1,000	1,000	1,000	1.5	1.3	1.7