

【施設維持管理情報 令和2年】

8月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土	175	175	175	1,000	1,001	1,000	1.2	1.7	2.1
2 日		174	175		1,000	1,000		1.5	1.7
3 月	175	173	173	1,000	1,000	1,000	1.5	1.7	1.2
4 火	175	175	170	1,000	1,000	1,000	2.0	1.9	1.0
5 水	175	174	175	1,000	1,000	1,000	2.1	2.0	1.0
6 木		174	175		1,000	1,002		2.3	1.5
7 金	175	175	174	1,000	1,000	1,000	1.5	2.1	2.3
8 土	175	174	174	1,000	1,000	1,002	1.0	1.5	1.3
9 日		175	175		1,000	1,000		1.7	1.9
10 祝	175	174	173	1,000	1,000	1,000	2.1	2.0	2.0
11 火	175	174	175	1,001	1,001	1,000	1.5	1.6	1.9
12 水	175	173	170	1,000	1,000	1,000	2.2	1.7	1.8
13 木									
14 金									
15 土									
16 日									
17 月	175	175	172	1,000	1,000	1,000	1.9	2.2	2.2
18 火	175	174	174	1,000	1,000	1,000	2.1	2.0	1.7
19 水	175	174	173	1,001	1,000	1,000	1.7	1.7	2.0
20 木	175	173	173	1,000	1,000	1,000	1.9	2.5	2.5
21 金			175			1,000			2.2
22 土	175	175	175	1,000	1,000	1,000	2.0	2.1	1.9
23 日	175	175	175	1,000	1,000	1,000	1.7	1.9	2.2
24 月	175	175	175	1,000	1,000	1,000	2.0	2.1	2.5
25 火	175	175	175	1,000	1,000	1,000	2.1	2.5	2.4
26 水	175	175	175	1,000	1,000	1,000	1.9	1.7	1.5
27 木	175	175	175	1,000	1,000	1,000	1.9	2.2	2.2
28 金	175	175	174	1,000	1,000	1,000	2.5	2.2	2.1
29 土	175	175	174	1,000	1,000	1,000	2.0	1.7	1.8
30 日		175	175		1,000	1,001		2.0	2.1
31 月	175	175	175	1,000	1,000	1,000	2.3	1.5	2.0