

【施設維持管理情報 令和2年】

10月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	175	175	175	1,000	1,000	1,000	2.0	1.7	1.5
2 金	175	175	175	1,000	1,000	1,000	2.2	2.1	1.9
3 土	175	175	175	1,000	1,000	1,000	2.0	1.2	2.0
4 日	175	173	175	1,000	1,000	1,000	1.9	1.5	1.2
5 月	175	175	174	1,000	1,000	1,000	2.2	2.1	2.5
6 火	175	173	173	1,001	1,001	1,000	2.5	2.1	1.2
7 水		175	174		1,000	1,000		1.5	1.7
8 木	175	174	175	1,000	1,001	1,001	2.1	2.0	1.9
9 金	175	177	170	1,000	1,001	1,000	2.1	2.5	2.7
10 土	175	175	175	1,000	1,000	1,000	1.8	1.9	2.2
11 日	175	170	175	1,000	1,000	1,000	1.5	2.1	2.2
12 月	175	175	172	1,000	1,000	1,000	1.9	2.0	1.7
13 火	175	175	175	1,000	1,000	1,000	2.2	2.3	2.5
14 水	175	175	174	1,000	1,000	1,000	2.0	1.7	1.5
15 木	175	175	174	1,000	1,000	1,000	1.2	1.5	1.2
16 金	175	174	174	1,000	1,000	1,000	2.0	2.1	2.3
17 土	175	174	170	1,000	1,000	1,000	1.5	1.7	2.0
18 日	175	175	175	1,000	1,000	1,000	2.1	1.9	2.0
19 月	175	174	177	1,001	1,001	1,002	1.5	1.5	1.3
20 火	175	175	175	1,001	1,000	1,000	2.0	2.0	2.1
21 水	175	175	175	1,000	1,001	1,002	2.0	1.7	1.3
22 木	175	175	174	1,000	1,000	1,000	1.7	1.5	1.5
23 金	175	175	175	1,000	1,000	1,000	2.1	1.9	2.0
24 土			175			1,000			2.0
25 日	175	175	175	1,000	1,000	1,000	2.0	1.7	1.5
26 月	175	175	175	1,000	1,000	1,000	1.8	1.9	2.0
27 火			175			1,000			2.2
28 水	175	175	174	1,000	1,000	1,000	1.7	1.2	1.5
29 木	175	175	173	1,000	1,000	1,000	2.3	1.3	2.0
30 金	175	175	175	1,000	1,000	1,000	2.0	1.9	1.7
31 土			175			1,000			1.7