

【施設維持管理情報 令和2年】

11月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	174	170	1,000	1,001	1,000	2.2	2.5	2.0
2 月	175	173	175	1,000	1,000	1,000	2.0	1.5	2.3
3 火	175	175	175	1,000	1,000	1,000	1.5	2.0	1.7
4 水	174	175	175	1,000	1,000	1,000	2.2	2.5	2.0
5 木	175	175	175	1,001	1,001	1,002	1.5	1.7	1.9
6 金	175	173	175	1,001	1,000	1,000	2.0	2.1	2.0
7 土	175	170	175	1,000	1,000	1,000	1.7	1.6	2.0
8 日	175	175	175	1,000	1,000	1,000	2.5	2.7	1.7
9 月	175	175	175	1,000	1,000	1,000	1.9	1.9	2.2
10 火	175	175	174	1,001	1,000	1,001	3.0	2.2	2.5
11 水	175	172	173	1,000	1,000	1,000	2.0	1.5	1.7
12 木	175	175	175	1,000	1,000	1,000	2.1	2.3	2.0
13 金	175	175	175	1,000	1,000	1,000	1.9	1.5	1.3
14 土	175	175	175	1,000	1,000	1,000	2.0	2.1	2.0
15 日	175	175		1,000	1,000		2.1	1.7	
16 月	175	175	175	1,000	1,000	1,000	2.3	2.0	2.0
17 火	175	175	175	1,000	1,000	1,000	1.9	1.7	2.0
18 水	175	175	174	1,001	1,001	1,000	2.0	1.3	1.5
19 木	175	170	175	1,000	1,001	1,000	1.9	1.8	2.4
20 金	175	175	173	1,000	1,000	1,000	2.0	2.0	1.9
21 土	175	175	175	1,000	1,000	1,000	1.5	1.6	1.9
22 日	175	175	174	1,000	1,000	1,000	2.2	2.4	2.0
23 祝		175	175		1,000	1,000		2.5	2.7
24 火	175	175	175	1,000	1,000	1,000	2.0	1.7	2.2
25 水	175	175	174	1,000	1,000	1,000	1.5	1.2	1.7
26 木	175	175	170	1,001	1,001	1,000	2.0	1.9	1.6
27 金	173	172	175	1,001	1,002	1,002	2.0	1.2	1.0
28 土	175	174	175	1,000	1,000	1,000	2.0	2.1	2.1
29 日	175	174	175	1,000	1,000	1,000	2.1	1.7	1.5
30 月	175	175	175	1,000	1,000	1,000	2.0	2.0	1.5