

【施設維持管理情報 令和2年】

12月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火	175	175	175	1,000	1,000	1,000	2.2	1.8	1.6
2 水	175	175	175	1,000	1,000	1,000	2.9	1.8	2.0
3 木	175	175	172	1,000	1,000	1,000	1.7	1.5	1.3
4 金			175			1,000			2.0
5 土		175	175		1,000	1,000		2.0	2.2
6 日	175	175	175	1,000	1,001	1,001	1.7	1.7	2.0
7 月	175	175	175	1,000	1,000	1,000	2.2	2.1	1.5
8 火	175	175	175	1,000	1,000	1,000	1.7	1.6	1.9
9 水	175	175	175	1,000	1,000	1,000	2.0	2.1	2.0
10 木	175	175	174	1,000	1,000	1,000	2.0	1.5	1.3
11 金	175	170	171	1,001	1,002	1,000	1.7	1.4	1.4
12 土	175	175	172	1,000	1,000	1,000	2.1	2.0	1.2
13 日	172	173	175	1,000	1,000	1,000	1.8	1.5	1.4
14 月	175	175	177	1,000	1,000	1,000	2.0	1.5	2.1
15 火	175	175	175	1,000	1,000	1,001	2.2	3.0	2.7
16 水	175	175	175	1,000	1,000	1,000	1.7	1.5	2.0
17 木	175	175	175	1,000	1,000	1,000	1.2	1.5	1.5
18 金	173	175	175	1,000	1,000	1,000	2.1	2.0	1.8
19 土	175	174	174	1,001	1,001	1,001	1.5	1.7	2.0
20 日	175	175	175	1,000	1,000	1,000	2.1	2.0	1.9
21 月	175	175	175	1,000	1,000	1,000	2.2	2.5	2.0
22 火	175	175	175	1,000	1,000	1,000	1.5	1.8	2.2
23 水	175	175	175	1,000	1,000	1,000	2.0	2.1	1.8
24 木	175	175	175	1,000	1,000	1,000	1.5	1.8	1.7
25 金	175	175	175	1,000	1,000	1,000	2.0	2.1	2.1
26 土	175	175	175	1,000	1,000	1,000	1.5	1.2	1.0
27 日	175	175	175	1,000	1,000	1,000	1.7	2.0	1.5
28 月	175	172	175	1,001	1,001	1,002	1.9	1.9	2.0
29 火									
30 水									
31 木									