

【施設維持管理情報 令和3年】

1月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 土									
3 日									
4 月									
5 火	175	175	175		1,000	1,000		2.5	2.2
6 水	175	175	172	1,000	1,000	1,000	2.1	1.7	1.9
7 木	175	175	175	1,000	1,000	1,000	2.1	1.7	1.5
8 金	175	175	175	1,000	1,000	1,000	2.1	2.0	2.5
9 土	175	175	175	1,000	1,001	1,002	1.5	1.2	1.0
10 日	170	172	175	1,000	1,001	1,000	1.2	0.8	0.9
11 祝	175	175	174	1,001	1,003	1,000	1.0	1.2	0.5
12 火	175	175	173	1,000	1,000	1,001	2.0	1.7	0.7
13 水	175	175	175	1,000	1,000	1,000	1.0	1.2	0.9
14 木	175	175	172	1,000	1,000	1,000	1.2	0.9	0.6
15 金	175	175	175	1,000	1,000	1,000	0.5	0.7	0.7
16 土	175	175	174	1,000	1,000	1,000	0.8	1.2	1.0
17 日	175	175		1,000	1,000		1.5	1.7	
18 月	175	175	175	1,000	1,000	1,000	1.2	1.0	0.8
19 火	175	175	175	1,000	1,000	1,000	1.0	0.5	1.2
20 水		175	175		1,000	1,000		0.7	1.0
21 木	175	175	172	1,000	1,000	1,000	2.0	1.5	1.0
22 金	175	177	175	1,001	1,001	1,002	1.7	0.8	1.2
23 土	175	175	175	1,000	1,000	1,000	1.2	1.5	0.9
24 日	175	175		1,000	1,000		2.0	1.9	
25 月			175			1,000			1.7
26 火	175	175	175	1,000	1,000	1,000	1.2	1.5	2.0
27 水	175	175	175	1,000	1,000	1,000	1.0	1.2	1.1
28 木	175	175	175	1,000	1,000	1,000	1.2	0.5	0.8
29 金	175	175	175	1,000	1,000	1,000	1.0	1.2	1.0
30 土	175	175	175	1,000	1,000	1,001	1.2	1.3	0.7
31 日	175	174	175	1,000	1,001	1,000	1.5	1.0	2.0