

【施設維持管理情報 令和3年】

2月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	175	175	1,000	1,000	1,000	1.2	1.5	2.0
2 火	175	175	175	1,000	1,000	1,000	2.0	0.2	1.8
3 水	175	175	175	1,000	1,000	1,000	1.5	1.7	2.0
4 木	175	175	175	1,000	1,000	1,000	1.2	1.0	1.0
5 金	175	175	175	1,000	1,000	1,000	0.7	1.2	1.7
6 土	175	175	175	1,000	1,000	1,000	1.2	1.5	1.1
7 日	175	175	175	1,000	1,001	1,001	1.5	2.0	2.0
8 月		175	170		1,000	1,000		1.9	1.2
9 火	175	175	173	1,001	1,002	1,001	1.0	0.9	0.7
10 水	175	175	175	1,000	1,000	1,000	2.0	1.7	1.2
11 祝	175	175	175	1,000	1,000	1,001	1.0	1.1	1.2
12 金	175	175	175	1,000	1,000	1,000	2.0	1.8	1.2
13 土	175	175	175	1,000	1,000	1,000	1.7	1.5	1.0
14 日	175	175	177	1,001	1,001	1,000	2.0	1.2	1.2
15 月	175	173	175	1,000	1,000	1,000	1.0	1.2	1.4
16 火	175	175	170	1,000	1,000	1,001	1.7	1.9	1.5
17 水	172	175		1,000	1,000		1.0	1.1	
18 木	175	175		1,000	1,000		2.0	1.7	
19 金		175	175		1,000	1,000		1.5	1.9
20 土	175	175		1,000	1,001		1.2	1.5	
21 日		175	175		1,000	1,000		2.0	1.7
22 月		175	175		1,000	1,000		1.7	1.5
23 祝		173	170		1,001	1,000		1.5	1.5
24 水		175	172		1,000	1,000		1.0	1.3
25 木		174	175		1,001	1,000		1.2	1.2
26 金		175	172		1,000	1,000		1.5	1.1
27 土	175	173		1,000	1,000		1.8	0.9	
28 日	175	175		1,000	1,000		2.0	1.7	
29									
30									
31									