

【施設維持管理情報 令和3年】

3月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	175		1,000	1,001		0.9	1.0	
2 火	175	175		1,000	1,000		1.2	1.5	
3 水	175	175	175	1,000	1,000	1,000	1.5	1.9	2.0
4 木	175	173	172	1,001	1,000	1,000	1.9	1.8	1.2
5 金	175	175	175	1,000	1,000	1,000	2.0	1.7	1.7
6 土	175	175	175	1,000	1,000	1,000	1.5	1.9	1.0
7 日	172	174	173	1,000	1,001	1,001	1.9	2.0	1.3
8 月	175	172	175	1,000	1,000	1,000	1.2	1.5	1.0
9 火									1.7
10 水	175	175	175	1,000	1,000	1,000	1.0	1.0	0.9
11 木	175	175	175	1,000	1,000	1,000	1.2	1.3	1.7
12 金	175	175	175	1,000	1,000	1,000	1.5	1.9	2.0
13 土	175	175	175	1,000	1,000	1,000	1.2	1.0	0.7
14 日			175			1,000			1.0
15 月	175	175	175	1,000	1,000	1,000	1.5	1.0	1.2
16 火	175	175	175	1,000	1,000	1,000	1.2	1.3	1.4
17 水	175	175	175	1,000	1,000	1,000	1.5	1.0	1.0
18 木	175	175	175	1,000	1,000	1,000	1.2	1.1	1.1
19 金	175	175	175	1,000	1,000	1,000	2.0	1.7	1.2
20 祝	175	175	170	1,000	1,000	1,000	1.2	1.0	0.9
21 日	175	175	175	1,001	1,000	1,000	1.0	1.2	2.1
22 月	175	173	177	1,000	1,000	1,001	1.0	1.5	2.0
23 火	175	175	175	1,000	1,000	1,000	1.5	1.9	1.3
24 水	175	175	175	1,000	1,000	1,000	1.2	1.0	1.2
25 木	175	175	175	1,000	1,000	1,000	1.7	1.5	1.1
26 金	175	175	175	1,000	1,000	1,000	1.0	0.9	0.8
27 土	175	175	175	1,000	1,000	1,000	1.2	1.5	1.7
28 日			175			1,000			2.0
29 月	175	175		1,000	1,000		1.7	1.2	
30 火	175	175	175	1,000	1,000	1,000	2.0	1.7	1.5
31 水	175	175	175	1,000	1,000	1,000	1.0	1.2	1.7