

【施設維持管理情報 令和3年】

4月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木			175			1,000			1.5
2 金	175	175	175	1,000	1,000	1,001	2.0	1.3	1.7
3 土	175	172	175	1,000	1,000	1,000	1.8	1.4	1.2
4 日	175	175	175	1,000	1,000	1,000	2.0	1.7	1.3
5 月			175			1,000			1.0
6 火	175	175	175	1,000	1,000	1,000	2.0	1.7	1.7
7 水	175	175	175	1,000	1,000	1,000	1.5	1.2	1.2
8 木	175	174	170	1,000	1,000	1,000	1.2	1.0	1.0
9 金	175	175	175	1,001	1,001	1,000	1.5	1.7	1.8
10 土	175	175	173	1,000	1,000	1,000	2.0	1.8	1.2
11 日	175	175	175	1,000	1,000	1,000	1.5	1.4	1.0
12 月	175	175	175	1,000	1,000	1,000	1.2	1.7	1.7
13 火	175	175	175	1,000	1,000	1,000	2.0	2.1	1.9
14 水	175	175	175	1,000	1,000	1,000	2.1	1.7	1.5
15 木			175			1,000			2.0
16 金	175	175	175	1,000	1,000	1,000	1.5	1.7	1.0
17 土		175	175		1,000	1,000		2.0	1.5
18 日		175	173		1,002	1,001		1.9	2.0
19 月	175	172		1,000	1,001	1,000	2.1	1.7	
20 火	175	175	175	1,000	1,000		1.0	1.2	1.1
21 水	175	175	175	1,000	1,000	1,000	1.2	0.9	1.0
22 木	175	175		1,000	1,000		1.0	1.5	
23 金	175	175	175	1,000	1,000	1,000	1.5	1.7	0.9
24 土	175	174	173	1,000	1,001	1,000	1.3	0.8	1.0
25 日	175	175	177	1,001	1,001	1,001	1.0	1.2	1.0
26 月	175	175	174	1,000	1,000	1,000	1.5	1.9	0.9
27 火	175	175	175	1,000	1,000	1,000	1.2	1.5	1.7
28 水	175	175	175	1,000	1,000	1,000	1.0	1.5	1.7
29 祝	175	175	175	1,000	1,000	1,000	1.0	0.9	1.2
30 金	175	175	175	1,000	1,000	1,000	1.0	1.1	1.5