

【施設維持管理情報 令和3年】

5月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土			175			1,000			1.0
2 日			175			1,000			1.2
3 祝									
4 祝									
5 祝									
6 木			175			1,000			2.0
7 金			175			1,000			1.7
8 土	175	175	175	1,001	1,000	1,000	1.0	1.1	1.5
9 日	175	175	175	1,000	1,000		1.5	0.9	
10 月	175	175	175	1,000	1,000	1,000	1.2	1.0	1.2
11 火	175	175	175	1,000	1,000	1,000	1.0	1.1	1.1
12 水		175	175		1,000	1,000		1.5	1.4
13 木	175	175	175	1,000	1,000	1,000	1.2	1.7	1.5
14 金	175	175	175	1,000	1,000	1,000	1.7	1.7	1.2
15 土	175	175	175	1,000	1,000	1,000	1.3	1.4	1.1
16 日	175	175		1,000	1,000		1.5	1.9	
17 月		175	175		1,000	1,000		2.0	1.7
18 火		175	175		1,000	1,000		1.7	1.5
19 水		175	175		1,000	1,000		1.5	1.0
20 木		175	175		1,000	1,000		1.2	1.2
21 金		175	177		1,001	1,000		1.0	0.8
22 土		175	175		1,000	1,000		1.5	1.3
23 日		175	172		1,001	1,000		1.2	2.0
24 月		173	175		1,001	1,001		1.0	1.8
25 火		175	175		1,000	1,000		1.7	1.5
26 水		175	175		1,000	1,000		1.5	1.8
27 木		175	175		1,000	1,000		2.0	1.8
28 金		172	172		1,000	1,000		1.7	1.7
29 土		175	175		1,000	1,000		1.5	1.7
30 日	175	173	175	1,000	1,000	1,000	1.7	1.0	1.2
31 月	175	175	175	1,000	1,000	1,000	1.0	1.1	1.5