

【施設維持管理情報 令和3年】

6月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度(二次焼却炉内、°C)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火	175	175	175	1,000	1,000	1,000	1.7	1.0	2.0
2 水	175	173	175	1,000	1,000	1,000	1.7	1.8	1.2
3 木	175	175	175	1,000	1,000	1,000	2.0	1.3	1.5
4 金	175	175	175	1,000	1,000	1,000	1.5	1.6	2.0
5 土	175	175	175	1,000	1,000	1,000	1.0	1.0	1.2
6 日	175	175		1,000	1,000		1.0	1.5	
7 月	173	175	175	1,000	1,000	1,000	0.9	1.0	1.1
8 火	175	175	175	1,000	1,000	1,002	1.0	1.5	1.5
9 水	175	175	175	1,000	1,000	1,000	1.5	1.2	1.7
10 木	175	175	175	1,000	1,000	1,000	1.9	1.5	1.3
11 金	175	175	175	1,000	1,000	1,000	2.0	1.7	1.0
12 土	175	175	175	1,000	1,000	1,000	1.5	1.4	1.0
13 日	175	175		1,000	1,000		1.5	1.9	
14 月	175	175	175	1,000	1,000	1,000	1.7	1.2	1.2
15 火	175	175	175	1,000	1,000	1,000	1.2	1.0	1.5
16 水	175	175	175	1,000	1,000	1,000	1.5	1.8	1.7
17 木	175	175	174	1,000	1,000	1,000	1.0	1.0	1.1
18 金	175	175	175	1,000	1,000	1,000	1.0	1.2	0.9
19 土	175	175	175	1,000	1,000	1,000	1.1	1.3	1.3
20 日			175			1,000			2.0
21 月	175	175	175	1,000	1,000	1,000	1.5	1.3	1.0
22 火	175	175	175	1,000	1,000	1,000	1.0	1.1	1.5
23 水	175	175	175	1,000	1,000	1,000	1.5	1.7	1.2
24 木	175	175	175	1,000	1,000	1,000	1.2	1.1	1.1
25 金	175	175	175	1,000	1,000	1,000	1.0	1.3	0.9
26 土	175	175	175	1,000	1,000	1,000	1.2	1.2	1.1
27 日	175	175	175	1,000	1,000	1,000	1.0	0.8	0.9
28 月	175	175	175	1,000	1,000	1,000	1.1	1.5	1.2
29 火	175	175	175	1,000	1,000	1,000	1.8	1.0	1.5
30 水	175	175	175	1,000	1,000	1,000	1.1	1.5	1.3