

【施設維持管理情報 令和3年】

7月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	175	175	175	1,000	1,000	1,000	0.8	1.7	1.5
2 金	175	175	175	1,000	1,000	1,000	1.0	1.1	1.5
3 土	175	175	175	1,000	1,000	1,000	1.2	1.5	1.0
4 日		175	175		1,000	1,000		1.8	1.2
5 月	175	175	173	1,000	1,000	1,000	1.5	2.0	1.0
6 火	175	175	174	1,001	1,001	1,000	0.9	1.2	1.3
7 水	175	175	175	1,000	1,000	1,000	1.2	1.3	1.7
8 木	175	175		1,000	1,001		1.0	0.8	
9 金	175	175	175	1,000	1,000	1,000	1.1	1.0	0.9
10 土	175	175	175	1,000	1,000	1,000	1.5	0.8	1.2
11 日	175	175	175	1,000	1,000	1,000	1.7	1.5	1.1
12 月	175	175		1,000	1,000		1.0	1.1	
13 火	175	175	175	1,000	1,000	1,000	1.5	1.3	1.9
14 水	175	175	175	1,000	1,000	1,000	1.2	1.5	1.0
15 木	175	175	175	1,000	1,000	1,000	1.0	0.8	1.0
16 金	175	175	175	1,000	1,000	1,000	1.2	1.3	1.5
17 土	175	175	175	1,000	1,000	1,000	1.4	2.0	1.0
18 日	175	173	175	1,000	1,000	1,000	1.5	1.8	1.5
19 祝	175	175	175	1,000	1,000	1,000	1.8	1.2	1.0
20 火	175	175	175	1,000	1,000	1,000	1.2	1.1	1.5
21 水	175	175	175	1,000	1,000	1,000	1.0	1.0	0.8
22 木	175	175	174	1,001	1,000	1,000	1.5	1.4	1.8
23 金	175	175	175	1,000	1,000	1,000	1.0	1.1	1.2
24 土	175	175	175	1,000	1,000	1,000	1.7	1.5	1.1
25 日		175	175		1,000	1,000		1.9	1.5
26 月	175	175	175	1,000	1,000	1,000	1.2	1.0	1.2
27 火	175	175	175	1,000	1,000	1,000	1.5	1.0	1.3
28 水	175	175	175	1,000	1,000	1,000	2.1	1.8	1.0
29 木	175	175	175	1,000	1,000	1,000	1.5	1.4	1.2
30 金	175	175	175	1,000	1,000	1,000	1.2	1.3	1.0
31 土	175	175	175	1,000	1,000	1,000	1.0	1.0	1.2