

【施設維持管理情報 令和3年】

8月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	175	175	1,000	1,000	1,000	1.2	1.5	1.5
2 月	175	175	175	1,001	1,000	1,001	1.0	1.7	0.9
3 火	175	175		1,000	1,000		1.2	1.5	
4 水	173	174	170	1,000	1,000	1,000	1.0	1.7	1.2
5 木	175	175	173	1,000	1,000	1,000	1.2	1.9	1.0
6 金	175	175	175	1,000	1,000	1,000	2.0	1.7	1.2
7 土	175	175	175	1,000	1,000	1,000	1.2	1.1	1.5
8 日	175	175	175	1,000	1,000	1,000	0.9	1.0	1.5
9 月	175	175	175	1,000	1,000	1,000	1.0	1.1	1.7
10 火	175	177	173	1,001	1,001	1,002	0.7	1.4	1.0
11 祝	175	175	177	1,000	1,000	1,000	1.9	1.3	1.2
12 木	175	175	175	1,000	1,000	1,000	1.9	2.2	1.5
13 金									
14 土									
15 日									
16 月	175	175		1,000	1,000		1.5	1.8	
17 火	175	175	175	1,000	1,000	1,000	2.2	1.7	2.0
18 水	175	175	175	1,000	1,000	1,000	1.7	1.8	1.0
19 木	175	175	172	1,000	1,000	1,000	1.5	1.2	1.5
20 金	175	175	175	1,000	1,000	1,000	1.2	1.0	1.2
21 土	175	175		1,000	1,000		2.1	1.7	
22 日	172	175	175	1,000	1,001	1,001	1.5	1.4	1.2
23 月	175	175	175	1,000	1,001	1,000	1.2	1.0	1.0
24 火	175	175	174	1,000	1,000	1,000	1.0	0.9	1.3
25 水	175	175	175	1,000	1,000	1,000	1.5	1.6	1.2
26 木	175	175	175	1,000	1,000	1,000	1.1	0.8	1.0
27 金	175	175	175	1,000	1,000	1,000	1.7	1.5	2.0
28 土	175	175	173	1,000	1,000	1,000	1.0	1.2	1.5
29 日									
30 月	175	175	175	1,000	1,000	1,000	1.0	1.1	1.9
31 火	175	175	172	1,000	1,000	1,000	1.5	0.8	1.0