

【施設維持管理情報 令和3年】

9月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	175	175	1,000	1,000	1,000	1.0	0.8	1.2
2 木	175	173	177	1,000	1,000	1,000	1.2	1.9	1.5
3 金	175	173	174	1,000	1,000	1,000	1.5	1.8	1.1
4 土	175	175	174	1,001	1,001	1,000	1.2	1.0	1.7
5 日		175	175		1,000	1,000		2.0	1.8
6 月	175	175	173	1,000	1,000	1,000	1.5	1.8	1.5
7 火	175	175	175	1,000	1,000	1,000	1.7	1.6	1.2
8 水	175	175	175	1,000	1,000	1,000	1.0	1.3	0.8
9 木	175	175	175	1,000	1,000	1,000	1.5	1.3	1.7
10 金	175	175	170	1,000	1,000	1,000	1.8	2.2	1.9
11 土	175	175	175	1,000	1,000	1,000	1.0	1.2	1.5
12 日	175	175	175	1,000	1,000	1,000	1.2	1.7	1.6
13 月	175	175	175	1,000	1,000	1,000	1.0	1.2	1.2
14 火	175	175	175	1,000	1,000	1,000	1.3	1.6	1.7
15 水	175	175	175	1,000	1,000	1,000	1.5	1.8	1.2
16 木	175	175	175	1,000	1,000	1,000	1.2	1.0	1.3
17 金	175	175	175	1,000	1,000	1,000	1.2	1.3	1.0
18 土	175	175	175	1,000	1,000	1,000	0.9	1.0	1.2
19 日	175	175		1,000	1,000		1.2	1.0	
20 祝									
21 火			175			1,000			1.5
22 水	175	175	175	1,000	1,000	1,000	2.0	2.0	1.8
23 祝	175	175	175	1,000	1,000	1,000	1.7	1.5	1.1
24 金	175	175	175	1,000	1,000	1,000	1.3	1.7	1.9
25 土	175	175	174	1,000	1,000	1,000	1.2	1.9	1.3
26 日	175	175	175	1,000	1,000	1,000	1.5	1.8	2.1
27 月	175	175	175	1,000	1,000	1,000	1.2	1.3	1.7
28 火	175	175	175	1,000	1,000	1,000	1.5	1.7	1.8
29 水	175	175	175	1,000	1,000	1,000	2.1	1.9	1.5
30 木	175	175	175	1,000	1,000	1,000	1.2	1.1	1.5