

【施設維持管理情報 令和3年】

10月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	175	175	175	1,000	1,000	1,000	1.0	1.2	1.9
2 土	175	175	175	1,000	1,000	1,000	1.7	1.8	2.1
3 日	175	175		1,000	1,000		1.5	1.8	
4 月		175	175		1,000	1,000		1.2	2.0
5 火		175	175		1,000	1,000		1.5	1.7
6 水		175	175		1,000	1,000		1.7	2.0
7 木	175	175	175	1,000	1,000	1,000	1.2	1.5	1.8
8 金	175	175	175	1,000	1,000	1,000	1.0	1.2	1.3
9 土	175	175	175	1,000	1,000	1,000	1.5	1.7	2.1
10 日	175	175	175	1,000	1,000	1,000	1.8	1.0	1.1
11 月	175	175	175	1,000	1,000	1,000	1.6	1.5	1.0
12 火	175	175	175	1,000	1,000	1,000	1.7	1.8	2.0
13 水	175	175	175	1,000	1,000	1,000	1.5	1.2	1.0
14 木	175	175	175	1,000	1,000	1,000	2.0	1.8	1.8
15 金	175	175	173	1,000	1,000	1,000	1.7	2.2	2.0
16 土	175	175	175	1,000	1,000	1,000	1.0	1.5	1.2
17 日	175	175	175	1,000	1,000	1,000	1.2	1.0	1.1
18 月	175	175	175	1,000	1,000	1,000	2.0	1.8	1.2
19 火	175	175	175	1,000	1,000	1,000	1.5	1.0	1.7
20 水	175	175	175	1,000	1,000	1,000	1.7	1.2	1.3
21 木	175	175	175	1,000	1,000	1,000	1.5	1.1	1.3
22 金	175	175	175	1,000	1,000	1,000	2.0	1.8	1.5
23 土	175	175	175	1,000	1,000	1,000	1.7	2.1	1.2
24 日	175	175	175	1,000	1,000	1,000	1.5	2.0	1.7
25 月	175	175	175	1,000	1,000	1,000	1.7	1.0	1.1
26 火	175	175	175	1,000	1,000	1,000	2.1	2.5	1.9
27 水	175	175	175	1,000	1,000	1,000	1.5	1.9	1.2
28 木	175	175	175	1,000	1,000	1,000	1.2	1.0	1.3
29 金	175	175	175	1,000	1,000	1,000	2.0	2.5	1.9
30 土	175	175	175	1,000	1,000	1,000	1.7	1.5	1.3
31 日	175	175	175	1,000	1,000	1,000	1.5	2.0	2.1