

【施設維持管理情報 令和3年】

11月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度(二次焼却炉内、℃)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	173	175	170	1,000	1,000	1,001	1.5	1.2	1.0
2 火	170	175	175	1,000	1,000	1,000	1.5	1.7	1.1
3 水	175	175	175	1,001	1,002	1,002	2.1	1.9	1.5
4 木	175	175	175	1,000	1,000	1,000	0.9	0.8	1.2
5 金	175	175	175	1,001	1,001	1,000	1.0	1.5	1.0
6 土	173	175	172	1,000	1,001	1,000	1.5	2.1	1.7
7 日	175	170	172	1,000	1,000	1,000	1.2	1.0	1.0
8 月	175	175	175	1,000	1,000	1,000	1.0	1.5	1.5
9 火	175	175	173	1,001	1,002	1,002	1.8	2.0	1.5
10 水	175	175	175	1,000	1,000	1,001	1.2	0.9	1.0
11 木	175	175	172	1,000	1,000	1,000	1.5	1.9	1.2
12 金	175	172	170	1,000	1,000	1,000	1.0	1.2	1.2
13 土		175	175		1,000	1,001		1.5	2.0
14 日	175	174	170	1,000	1,000	1,000	0.8	1.2	1.0
15 月	175	175	175	1,001	1,000	1,001	1.0	1.5	0.9
16 火	175	175	175	1,000	1,000	1,000	0.5	0.3	0.7
17 水	172	175	170	1,001	1,001	1,000	1.2	0.9	1.0
18 木	175	173	174	1,000	1,000	1,000	1.0	1.1	1.5
19 金	175	175	175	1,000	1,000	1,000	1.0	0.5	0.7
20 土	175	170	171	1,001	1,002	1,002	1.2	1.0	1.0
21 日	175	175	174	1,000	1,001	1,000	0.9	0.6	1.2
22 月	175	175	175	1,000	1,000	1,000	1.0	1.3	1.7
23 祝		175	175	1,000	1,001	1,000	1.0	1.2	1.9
24 水	175	175	175	1,000	1,000	1,000	0.8	0.5	1.1
25 木	175	175	173	1,001	1,002	1,002	1.2	1.0	0.8
26 金	175	170	172	1,000	1,000	1,000	1.5	1.3	1.0
27 土	175	175	173	1,001	1,001	1,000	1.0	0.7	1.3
28 日	175	175		1,000	1,000		1.5	1.2	
29 月	172	175	173	1,001	1,000	1,000	1.0	1.7	1.0
30 火	175	175	175	1,000	1,000	1,000	1.2	1.5	1.3