

【施設維持管理情報 令和3年】

12月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度(二次焼却炉内、°C)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	175	175	1,000	1,000	1,000	1.5	1.8	2.1
2 木	173	175	175	1,000	1,000	1,001	1.0	0.9	1.5
3 金	175	175	175	1,000	1,000	1,000	1.2	1.5	1.9
4 土	170	175	173	1,001	1,001	1,002	1.0	0.7	0.5
5 日	175	172	175	1,001	1,000	1,001	1.5	1.9	0.9
6 月	175	175	174	1,000	1,000	1,000	1.3	1.7	1.8
7 火	175	175	175	1,000	1,000	1,000	1.8	1.2	1.0
8 水	175	175	175	1,000	1,000	1,000	2.0	1.8	1.5
9 木	175	175	175	1,000	1,000	1,000	1.2	1.5	1.7
10 金	172	175	177	1,000	1,001	1,000	1.0	1.2	1.1
11 土	175	175	175	1,000	1,000	1,000	1.5	1.0	0.8
12 日	175	175		1,000	1,000		1.8	1.2	
13 月	175	175	175	1,002	1,001	1,001	1.4	1.5	1.0
14 火	172	175	175	1,000	1,000	1,000	1.2	0.8	0.5
15 水	175	175	173	1,000	1,000	1,000	1.2	1.5	1.7
16 木	172	170		1,000	1,000		1.8	2.0	
17 金									
18 土									
19 日									
20 月									
21 火									
22 水									
23 木									
24 金									
25 土									
26 日									
27 月									
28 火									
29 水									
30 木									
31 金									