

【施設維持管理情報 令和4年】

2月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度(二次焼却炉内、°C)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火									
2 水									
3 木									
4 金									
5 土									
6 日									
7 月									
8 火									
9 水									
10 木		175	175		1,000	1,000		1.0	1.0
11 祝	175	175	175	1,000	1,000	1,001	1.2	1.3	1.0
12 土	175	175	173	1,000	1,000	1,000	1.0	1.5	1.1
13 日		175	170		1,002	1,000		1.0	0.7
14 月	173	172	170	1,000	1,000	1,000	1.5	1.0	1.0
15 火	170	175	172	1,000	1,001	1,000	2.0	1.2	1.5
16 水	175	175	173	1,000	1,000	1,000	1.2	1.5	1.5
17 木	172	172	175	1,000	1,000	1,000	1.0	2.0	1.7
18 金	174	177	171	1,001	1,001	1,000	0.7	2.5	1.3
19 土	175	179	175	1,001	1,000	1,000	0.8	1.4	0.9
20 日	175	175	175	1,002	1,000	1,000	1.2	1.5	1.0
21 月	175	175	175	1,000	1,000	1,000	1.3	1.3	1.3
22 火	175	175	175	1,003	1,000	1,000	1.5	1.2	1.6
23 祝	170	175	170	1,000	1,000	1,000	1.9	0.5	1.2
24 木	172	179	175	1,000	1,000	1,000	1.0	2.0	1.7
25 金	175	177	175	1,000	1,000	1,000	1.2	1.7	1.8
26 土	175	170	175	1,000	1,000	1,000	2.2	1.3	1.2
27 日	175	175	172	1,000	1,000	1,000	1.9	1.5	1.0
28 月	172	175	170	1,000	1,000	1,000	2.1	1.2	1.0