

【施設維持管理情報 令和4年】

5月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日									
2 月		175	175		1,000	1,000		1.5	1.2
3 祝									
4 祝									
5 祝									
6 金			173			1,000			1.0
7 土			170			1,000			1.1
8 日									
9 月	175	175	176	1,000	1,000	1,000	1.5	1.7	1.0
10 火		175	170		1,000	1,000		1.3	1.5
11 水	175	175	171	1,000	1,000	1,000	1.7	1.0	1.3
12 木		175		1,000	1,000		1.0	0.8	
13 金	175	172	175		1,000	1,000		1.0	1.2
14 土	177	170	173	1,000	1,000	1,000	1.3	1.3	
15 日	175	175		1,000	1,000		1.5	1.2	
16 月		171	174		1,000	1,000		1.0	1.7
17 火	170	172	175	1,000	1,000	1,000	1.9	1.7	2.0
18 水	175	175	175	1,000	1,000	1,000	1.5	1.6	1.6
19 木	173	175	175	1,000	1,000	1,001	1.0	1.2	2.1
20 金	175	175	175	1,000	1,001	1,001	0.8	1.2	1.5
21 土	170	175	175	1,000	1,000	1,000	0.9	1.0	1.2
22 日		179	175		1,000	1,000		0.8	1.0
23 月		175	172		1,000	1,000		0.9	1.2
24 火		179	179		1,000	1,000		0.9	1.5
25 水	175	175	175	1,000	1,000	1,000	1.2	1.0	1.3
26 木	172	175	178	1,000	1,000	1,000	1.7	1.7	1.0
27 金	177	175	170	1,001	1,001	1,002	0.8	1.0	1.0
28 土	176	175	175	1,000	1,000	1,000	1.5	1.0	2.1
29 日	175	175		1,000	1,000		1.5	1.5	
30 月		172	175		1,000	1,001		1.3	1.5
31 火	175	175	175	1,000	1,000	1,000	1.1	1.3	1.3