

【施設維持管理情報 令和4年】

7月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金		175	175		1,000	1,000		1.2	1.3
2 土	175	175	175	1,000	1,000	1,000	0.8	1.0	1.2
3 日									
4 月		172	175		1,000	1,000		1.7	1.0
5 火		175	175		1,000	1,000		1.2	1.0
6 水	175	175	175	1,000	1,000	1,000	1.5	1.0	0.9
7 木	175	177	171	1,000	1,000	1,000	1.2	0.8	0.8
8 金	175	175	175	1,000	1,000	1,000	1.7	1.5	1.2
9 土		175	175		1,000	1,000		1.2	1.0
10 日		175	177					1.9	1.5
11 月		175	175		1,000	1,000		1.0	0.8
12 火		177	175		1,000	1,000		2.1	1.0
13 水		173	175		1,000	1,000		1.9	1.2
14 木		175	175		1,000	1,000		1.7	0.5
15 金	175	175	175	1,000	1,000	1,000	1.3	1.3	1.3
16 土		170	175		1,000	1,000		1.0	1.3
17 日									
18 祝	175	175		1,000	1,000		0.5	1.0	
19 火		175	175		1,000	1,000		1.1	1.3
20 水		175	175		1,000	1,000		1.0	0.7
21 木	175	175	175	1,000	1,000	1,000	0.9	1.5	1.2
22 金	175	175	175	1,000	1,000	1,000	1.0	1.2	1.0
23 土	175	174	175	1,000	1,000	1,000	1.3	0.5	0.7
24 日		175	175		1,000	1,000		0.9	0.8
25 月		175	175		1,000	1,000		1.2	1.0
26 火	175	175	175	1,000	1,000	1,000	1.0	0.8	1.1
27 水		175	175		1,000	1,000		0.5	1.0
28 木	175	175	175	1,000	1,000	1,000	1.2	1.0	1.2
29 金		175	175		1,000	1,000		1.1	0.9
30 土		175	175		1,000	1,000		1.0	1.2
31 日									