

【施設維持管理情報 令和4年】

8月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度(二次焼却炉内、°C)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	175	175	1,000	1,000	1,000	1.2	1.0	1.5
2 火		177	175		1,000	1,000		0.8	1.0
3 水	175	170	175	1,000	1,000	1,000	1.0	1.5	1.4
4 木		173	175		1,000	1,000		1.3	1.8
5 金	175	175	176	1,000	1,000	1,000	1.3	1.0	1.0
6 土									
7 日									
8 月		173	174		1,000	1,000		2.1	1.7
9 火	175	175	177	1,000	1,000	1,000	1.0	1.5	1.2
10 水		175	174		1,000	1,000		0.9	0.5
11 祝	175	175	177	1,000	1,000	1,000	0.8	1.2	1.0
12 金	175	172	176	1,000	1,000	1,000	1.3	1.0	0.9
13 土									
14 日									
15 月									
16 火		175	175		1,000	1,000		1.5	1.3
17 水		172	175		1,000	1,000		1.0	0.7
18 木		175	173		1,000	1,000		1.5	1.7
19 金	175	175	175	1,000	1,000	1,000	2.1	1.9	2.0
20 土		175	175		1,000	1,000		1.0	0.8
21 日									
22 月		175	175		1,000	1,000		1.2	1.5
23 火		173	175		1,000	1,000		1.3	0.9
24 水	175	175	175	1,000	1,000	1,000	1.0	1.3	0.8
25 木		175	175		1,000	1,000		1.0	1.0
26 金	170	175	175	1,000	1,000	1,000	1.3	1.5	1.2
27 土	172	173	175	1,000	1,000		0.8	0.9	
28 日									
29 月	175	175	175	1,000	1,000	1,000	0.9	1.0	1.2
30 火		175	175		1,000	1,000		1.0	1.0
31 水	172	175	173	1,000	1,000	1,000	1.2	1.3	1.5