

【施設維持管理情報 令和4年】

10月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土									
2 日									
3 月									
4 火									
5 水									
6 木									
7 金	175	175		1,000	1,000		1.5	2.1	
8 土		177	175		1,000	1,000		1.7	1.6
9 日	175	175	175	1,000	1,000	1,000	2.5	2.3	1.0
10 祝	175	175	175	1,000	1,000	1,000	1.3	1.2	1.0
11 火	177	175	175	1,000	1,000	1,000	1.5	1.5	1.2
12 水	173	172	172	1,000	1,000	1,000	1.2	1.9	1.3
13 木	175	179	175	1,000	1,000	1,000	1.2	1.5	2.1
14 金	170	175	175	1,000	1,000	1,000	0.9	2.3	2.0
15 土	175	175		1,000	1,000		1.8	2.0	
16 日	175	175	175	1,000	1,000	1,000	2.1	2.1	1.9
17 月	175	175	172	1,000	1,000	1,000	2.5	2.5	1.3
18 火	175	175	173	1,000	1,000	1,000	2.7	1.7	2.1
19 水	175	177	175	1,000	1,000	1,000	2.0	0.9	2.5
20 木	172	175	175	1,000	1,000	1,000	1.9	1.0	1.9
21 金	175	173	175	1,000	1,000	1,000	1.7	1.5	1.0
22 土			175			1,000			1.3
23 日									
24 月	175	172	178	1,000	1,000	1,000	2.1	1.7	1.5
25 火	175	170	175	1,000	1,000	1,000	0.8	1.5	1.4
26 水	175	175	175	1,000	1,000	1,000	2.1	1.3	1.7
27 木	175	177	172	1,000	1,000	1,000	1.7	1.0	2.1
28 金	175	179	170	1,000	1,000	1,000	1.5	1.7	2.3
29 土	175	175		1,000	1,000		1.3	0.7	
30 日	175	175	172	1,000	1,000	1,000	1.0	1.1	2.5
31 月	176	175	175	1,000	1,000	1,000	1.5	1.0	1.1