

【施設維持管理情報 令和4年】

11月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火	175	175	172	1,000	1,000	1,000	1.5	0.3	1.0
2 水	175	170	171	1,002	1,000	1,001	1.0	1.2	0.8
3 祝	172	175	175	1,000	1,000	1,000	2.0	1.8	1.5
4 金	175	175	177	1,001	1,000	1,000	0.9	0.8	1.2
5 土	172	173	175	1,005	1,000	1,000	1.3	1.5	1.2
6 日									
7 月	175	175	175	1,000	1,002	1,000	1.0	1.1	1.5
8 火	175	172	175	1,000	1,001	1,000	2.0	1.7	1.0
9 水	170	178	175	1,000	1,000	1,000	1.0	0.5	0.7
10 木	175	175	175	1,000	1,000	1,000	1.2	1.0	1.2
11 金	175	172	175	1,002	1,003	1,000	0.8	0.6	1.0
12 土	175	174	175	1,007	1,005	1,000	1.0	1.2	1.5
13 日			175			1,003			2.0
14 月	175	175	175	1,000	1,000	1,004	1.5	1.3	1.0
15 火	175	175	172	1,000	1,001	1,000	0.5	0.8	1.2
16 水			175	1,000	1,000	1,001			1.0
17 木	175	175	170	1,000	1,000	1,000	0.5	1.3	0.8
18 金	172	176	172	1,000	1,002	1,002	1.0	1.3	1.0
19 土	177	175	171	1,001	1,000	1,004	2.0	2.1	1.2
20 日	175	175		1,000	1,000		0.5	1.0	
21 月			175			1,000			1.0
22 火	175	175	175	1,001	1,000	1,000	1.2	1.3	1.5
23 祝	175	175	175	1,005	1,000	1,000	0.8	1.5	1.0
24 木	178	175	173	1,000	1,000	1,000	1.0	1.1	1.0
25 金	179	175	175	1,003	1,000	1,000	0.8	0.6	1.1
26 土	175	175	175	1,000	1,000	1,000	2.1	1.7	1.0
27 日									
28 月	172	175	172	1,000	1,002	1,000	1.0	0.6	0.8
29 火	175	175	175	1,001	1,000	1,000	1.5	1.3	2.1
30 水	175	175	175	1,001	1,000	1,000	0.3	0.5	1.0