

【施設維持管理情報 令和4年】

12月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度(二次焼却炉内、°C)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	175	175	175	1,000	1,000	1,000	1.5	1.0	1.0
2 金	175	175	173	1,000	1,000	1,000	1.2	1.1	2.1
3 土	177	172	175	1,000	1,000	1,000	0.8	1.5	1.5
4 日									
5 月	175	175	175	1,000	1,000	1,000	1.3	1.7	1.5
6 火	175	172	175	1,000	1,000	1,000	1.0	1.5	1.2
7 水	177	175	175	1,000	1,000	1,000	0.9	1.0	1.4
8 木	174	175	174	1,000	1,000	1,000	1.0	1.2	1.5
9 金	175	175	172	1,000	1,000	1,000	1.2	1.2	1.7
10 土	172	175	170	1,000	1,000	1,000	1.3	1.0	1.9
11 日									
12 月	175	175	175	1,000	1,000	1,000	1.5	1.7	2.0
13 火	175	175	175	1,000	1,000	1,000	1.0	1.2	1.7
14 水			175						1.5
15 木	175	175	175	1,000	1,000	1,000	1.0	1.0	1.5
16 金	175	175	175	1,000	1,000	1,000	1.0	1.1	1.1
17 土	175	172	174	1,000	1,000	1,000	0.7	0.7	1.7
18 日	174	175		1,000	1,000		0.5	1.0	
19 月	175	172	175	1,000	1,000	1,000	1.0	1.3	1.7
20 火	179	173	175	1,000	1,000	1,000	1.2	1.5	1.0
21 水	174	174	174	1,000	1,000	1,000	1.5	1.2	1.2
22 木	175	175	170	1,000	1,000	1,000	1.0	1.3	1.0
23 金		175	175		1,000	1,000		1.2	0.8
24 土	175	175	175	1,000	1,000	1,000	1.2	1.1	0.8
25 日									
26 月	175	175	175	1,000	1,000	1,000	1.0	1.7	1.0
27 火	175	175	175	1,000	1,000	1,000	1.2	1.5	1.2
28 水	176	172	175	1,000	1,000	1,000	1.3	1.2	1.0
29 木	175	175	175	1,000	1,000	1,000	0.9	0.8	1.5
30 金									
31 土									