

【施設維持管理情報 令和5年】

1月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 月									
3 火									
4 水									
5 木	175	175	174	1,000	1,000	1,000	0.8	0.9	1.5
6 金	175	173	175	1,000	1,000	1,000	1.2	1.2	1.0
7 土	175	175	170	1,000	1,000	1,000	1.0	1.0	1.5
8 日									
9 祝	175	175	170	1,000	1,000	1,000	1.0	0.8	1.0
10 火	175	176	174	1,000	1,000	1,000	1.2	1.0	1.7
11 水	175	174	173	1,000	1,000	1,000	1.5	1.1	1.6
12 木	172	177	172	1,000	1,000	1,000	1.2	1.5	1.0
13 金	173	175	173	1,000	1,000	1,000	1.4	1.7	1.2
14 土	175	175		1,000	1,000		1.3	1.3	
15 日	175	175		1,000	1,000		0.9	1.0	
16 月		175	174		1,000	1,000		1.0	1.2
17 火		175	174		1,000	1,000		1.5	1.3
18 水	172	175	175	1,000	1,000	1,000	0.8	1.3	1.5
19 木	174	174	175	1,000	1,000	1,000	0.7	1.7	1.4
20 金	175	175	175	1,000	1,000	1,000	1.0	1.5	1.3
21 土	175	175	175	1,000	1,000	1,000	1.3	1.0	1.2
22 日									
23 月	174	175	175	1,000	1,000	1,000	1.9	1.7	1.2
24 火	173	175	0.174	1,000	1,000	1,000	1.2	1.0	1.1
25 水	175	175	175	1,000	1,000	1,000	1.3	1.0	1.3
26 木									
27 金			175			1,000			1.0
28 土	170	174	175	1,000	1,000	1,000	1.3	1.0	1.2
29 日	175	175		1,000	1,000		1.5	1.2	
30 月	175	175	175	1,000	1,000	1,000	1.6	1.3	1.0
31 火	175	170	175	1,000	1,000	1,000	1.7	1.5	0.8