

【施設維持管理情報 令和5年】

2月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	175	175	1,000	1,000	1,000	1.0	1.2	1.3
2 木	175	175	175	1,000	1,000	1,000	1.2	0.8	0.8
3 金	175	173	175	1,000	1,000	1,000	0.8	0.9	1.0
4 土	175	175	175	1,000	1,000	1,000	1.5	0.5	1.3
5 日	174	175	175	1,000	1,000	1,000	0.9	1.0	1.5
6 月	175	175	174	1,000	1,000	1,000	1.0	0.3	0.8
7 火	177	175	175	1,000	1,000	1,000	1.2	0.9	0.5
8 水	175	175	177	1,000	1,000	1,000	1.5	0.3	0.5
9 木	175	175	175	1,000	1,000	1,000	1.7	0.3	1.0
10 金	175	174	173	1,000	1,000	1,000	0.9	0.9	1.9
11 土	175	175	174	1,000	1,000	1,000	1.0	1.2	1.2
12 日		174	175		1,000	1,000		1.1	1.1
13 月	175	173	175	1,000	1,000	1,000	1.5	1.5	1.4
14 火	175	176	175	1,000	1,000	1,000	1.0	1.0	1.0
15 水	172	175	175	1,000	1,000	1,000	1.3	1.3	1.0
16 木	175	175	175	1,000	1,000	1,000	1.2	0.7	0.9
17 金	176	175	175	1,000	1,000	1,000	1.0	0.6	1.0
18 土	175	175	175	1,000	1,000	1,000	0.8	1.0	1.0
19 日									
20 月	175	175	175	1,000	1,000	1,000	1.3	1.0	1.0
21 火			175			1,003			2.0
22 水	175	175	175	1,000	1,000	1,000	1.0	0.9	1.5
23 祝	175	175	175	1,000	1,000	1,000	1.3	1.0	1.0
24 金			174			1,000			0.8
25 土	175	175	175	1,000	1,000	1,000	1.0	1.5	0.7
26 日	175	175		1,000	1,000		2.1	1.3	
27 月	175	175	175	1,000	1,000	1,000	0.8	1.0	1.0
28 火	172	175	175	1,000	1,000	1,000	1.0	1.3	1.5