

【施設維持管理情報 令和5年】

3月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	175	175	1,000	1,000	1,000	1.0	1.3	0.9
2 木	175	175	175	1,000	1,000	1,000	1.2	1.5	1.0
3 金	175	175	175	1,000	1,000	1,000	1.0	1.0	1.0
4 土	175	175	175	1,000	1,000	1,000	1.2	0.8	1.2
5 日									
6 月	175	175	175	1,000	1,000	1,000	1.3	1.0	1.7
7 火	175	175	175	1,000	1,000	1,000	1.4	1.9	1.2
8 水			175			1,000			1.3
9 木									
10 金									
11 土									
12 日									
13 月	175	175	175	1,000	1,000	1,000	1.7	1.7	1.5
14 火	175	175	175	1,000	1,000	1,000	1.5	1.3	2.1
15 水	175	175	175	1,000	1,000	1,000	1.7	1.5	1.3
16 木	175	175	175	1,000	1,000	1,000	1.2	1.0	1.5
17 金	175	175	175	1,000	1,000	1,000	1.7	0.9	2.0
18 土	175	175	175	1,000	1,000	1,000	1.0	0.8	1.9
19 日									
20 月	175	175	175	1,000	1,000	1,000	1.7	1.7	1.5
21 祝	175	175		1,000	1,000		1.2	1.5	
22 水	175	175	175	1,000	1,000	1,000	1.2	1.0	1.0
23 木	175	175	175	1,000	1,000	1,000	1.3	0.9	1.0
24 金	175	175	175	1,000	1,000	1,000	1.0	1.0	2.1
25 土	175	175	175	1,000	1,000	1,000	1.9	0.8	1.7
26 日									
27 月	175	175	175	1,000	1,000	1,000	1.0	1.3	1.5
28 火	175	175	175	1,000	1,000	1,000	1.3	1.7	2.1
29 水	175	175	175	1,000	1,000	1,000	1.5	1.6	2.0
30 木	175	175	175	1,000	1,000	1,000	1.0	1.4	1.7
31 金	175	175	175	1,000	1,000	1,000	1.4	0.8	1.5