

【施設維持管理情報 令和5年】

5月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度(二次焼却炉内、°C)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月		155	177		800	1,000	0.0	2.0	0.5
2 火	174	180	175	999	1,000	1,000			
3 祝									
4 祝									
5 祝									
6 土									
7 日									
8 月	172	175	174	1,001	999	1,000	0.3	1.1	0.2
9 火		176	172		989	1,001		1.8	0.1
10 水	175	177	174	1,000	997	999	1.2	0.8	0.3
11 木	177	171	175	996	1,001	1,003	2.0	0.1	0.3
12 金	172	175	176	1,000	998	999	1.7	2.2	1.1
13 土	174	175	173	1,000	997	825	0.9	0.7	2.8
14 日									
15 月	176	174	174	997	999	1,000	2.1	1.1	1.5
16 火	175	174	176	995	998	901	0.5	0.8	3.0
17 水	173	175	175	1,000	997	996	1.0	1.2	0.8
18 木	175	174	175	1,001	998	997	1.3	0.3	0.4
19 金		176	174		910	1,000		2.2	0.9
20 土	173	174	177	997	999	1,000	1.8	0.5	0.1
21 日									
22 月	174	175	175	998	1,000	999	1.2	0.6	0.4
23 火		174	173		997	998		1.8	0.5
24 水		173	175		998	1,000		1.1	0.8
25 木		174	175		1,000	997		0.9	0.0
26 金		175	174		997	996		0.8	0.3
27 土	175	173	176	900	998	997	2.8	0.7	0.5
28 日									
29 月		174	175		998	1,000		1.0	0.9
30 火		173	174		1,000	1,001		0.1	0.3
31 水		174	175		997	999		1.3	0.1