

【施設維持管理情報 令和5年】

7月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度(二次焼却炉内、°C)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土		174	176		1,000	1,000		1.0	0.0
2 日		178	175		998	999		0.0	2.0
3 月	175	176	177	1,001	1,000	999	1.0	0.0	0.0
4 火		177	176		1,000	997		2.0	1.0
5 水	175	175	174	1,000	1,000	998	2.0	1.0	0.0
6 木	178	177	176	999	1,000	1,000	0.0	0.0	1.0
7 金		175	176		998	999		1.0	3.0
8 土	176	175	177	1,000	997	1,000	0.0	0.0	1.2
9 日									
10 月	175	174	176	998	1,000	999	0.0	1.0	0.0
11 火		176	177		999	1,001		0.0	0.0
12 水	175	176	176	1,003	1,000	999	0.0	0.0	1.0
13 木	177	176	175	1,009	1,000	1,000	2.1	0.0	0.0
14 金	178	175	174	1,000	998	999	0.0	0.0	0.0
15 土	175	174	177	997	1,000	1,001	0.0	1.0	0.0
16 日	176	176	175	1,008	997	1,000	0.0	0.0	0.0
17 祝		175	176		1,000	997		1.0	0.0
18 火		176	178		1,001	1,000		0.0	0.0
19 水	175	176	177	999	1,000	1,000	0.0	1.0	0.0
20 木		177	178		1,009	1,000		0.0	0.0
21 金	177	176	175	1,000	1,000	1,000	0.0	0.0	0.0
22 土	176	175	174	996	999	1,000	0.0	1.0	1.3
23 日									
24 月									
25 火									
26 水	175	176	175	1,000	1,000	1,000	0.0	0.0	0.0
27 木	178	177	175	1,002	1,000	1,000	0.0	1.0	0.7
28 金	176	176	175	997	999	1,000	0.0	0.0	0.0
29 土	175	177	178	999	1,000	1,001	1.0	0.0	0.0
30 日									
31 月	178	176	175	1,008	1,000	998	0.0	0.0	0.0