

【施設維持管理情報 令和5年】

8月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度(二次焼却炉内、℃)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火		174	171		998	1,000		1.0	0.0
2 水	173	170	169	1,000	1,001	1,000	1.0	0.0	0.0
3 木	171	170	170	1,000	999	1,001	2.0	1.0	0.0
4 金	174	173	170	999	1,000	1,000	1.0	0.0	0.0
5 土		170	173		998	999		2.0	0.0
6 日		173	174		1,000	1,000		1.0	0.0
7 月	172	171	171	1,001	999	1,001	0.0	0.0	0.0
8 火	173	170	172	1,000	1,000	1,000	1.0	1.0	0.0
9 水	170	172	171	998	997	999	0.9	0.0	0.0
10 木	173	172	172	1,000	1,000	1,002	3.0	0.0	1.0
11 祝									
12 土									
13 日									
14 月									
15 火		171	169		998	1,000		1.1	0.0
16 水	171	170	170	1,000	1,000	1,000	2.0	0.0	0.0
17 木		172	171		1,000	999		0.0	0.0
18 金	172	170	170	1,000	1,000	1,000	1.0	0.0	1.0
19 土	170	171	171	1,000	999	900	0.0	0.0	0.0
20 日	173	170	169	999	1,000	920	1.0	0.0	0.0
21 月		170	171		1,000	1,000		3.0	0.0
22 火	170	170	171	998	1,000	1,000	1.0	0.0	0.0
23 水	171	170	169	1,000	1,000	1,000	0.8	0.0	0.0
24 木	172	171	170	1,000	999	999	3.0	0.0	0.0
25 金	171	171	170	997	1,000	998	1.0	0.0	0.0
26 土	170	170	172	1,000	1,000	910	0.7	1.0	0.0
27 日									
28 月	168	172	171		1,000	1,002	0.0	0.0	0.0
29 火	171	170	170	1,003	999	1,000	3.0	0.0	0.0
30 水	172	171	171	999	1,000	1,000	0.6	0.0	0.0
31 木	170	169	169	1,000	1,000	999	1.0	0.0	0.0