

【施設維持管理情報 令和5年】

9月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	174	175	168	1,000	1,000	1,002	0.0	0.0	1.0
2 土	175	174	176	999	1,000	1,000	0.5	1.0	0.0
3 日	174	175	175	1,000	1,000	999	0.0	0.0	0.0
4 月	177	176	175	1,000	997	1,001	5.0	0.0	1.0
5 火	174	175	176	1,001	1,000	1,000	0.0	0.0	0.0
6 水	174	175	177	1,000	999	998	0.0	0.0	0.0
7 木		178	177		1,000	1,000		1.0	0.0
8 金	175	175	176	998	1,001	1,000	1.0	0.0	1.0
9 土	168	170	175	1,000	1,000	997	0.0	0.0	0.0
10 日									
11 月	169	174	176	1,000	998	1,000	0.0	0.0	0.0
12 火	175	175	174	1,000	1,002	1,000	1.0	1.0	0.0
13 水	174	174	175	1,002	999	998	0.0	0.0	1.0
14 木	176	175	175	1,000	1,000	1,000	0.0	0.0	0.0
15 金	175	175	174	999	1,001	1,000	1.0	1.0	2.0
16 土	176	175	175	1,000	1,000	999	3.0	0.0	0.0
17 日									
18 祝									
19 火	175	175	175	998	1,000	1,001	0.0	0.0	0.0
20 水	174	175	176	1,000	1,000	1,000	0.0	0.0	0.0
21 木	176	176	175	1,000	1,001	998	1.0	1.0	2.0
22 金	174	174	175	1,001	1,003	1,000	0.0	0.0	0.0
23 祝	175	175	176	1,000	1,000	965	0.0	0.0	0.0
24 日									
25 月	178	177	175	1,000	1,000	1,000	0.0	1.0	0.0
26 火	176	170	176	970	1,000	1,000	11.0	0.0	0.0
27 水		175	174		1,000	1,000		0.0	1.0
28 木	175	174	175	1,000	998	999	0.0	0.0	0.0
29 金	176	175	175	999	1,000	1,000	1.0	0.0	0.0
30 土	174	175	175	1,000	1,000	998	0.0	0.0	0.0