

【施設維持管理情報 令和5年】

11月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水		170	171		999	1,000		1.0	0.0
2 木	168	170	172	1,000	1,000	998	1.0	0.0	0.0
3 祝	170	171	170	1,000	1,001	1,000	0.0	0.0	0.0
4 土	167	170	171	1,000	1,000	990	0.0		1.0
5 日								2.0	
6 月		170	172		1,000	999		0.0	1.0
7 火		169	167		1,000	1,000		0.0	0.0
8 水		168	170		1,000	1,000		0.0	0.0
9 木	169	170	171	998	1,002	1,000	1.0	1.0	1.0
10 金		170	170		1,000	999		0.0	0.0
11 土	170	171	170	1,000	1,000	1,000	0.0		0.0
12 日								0.0	
13 月	168	170	169	1,000	1,000	989	0.0	0.0	2.0
14 火		168	167		1,000	1,000		1.0	0.0
15 水		170	171		998	1,001		0.0	0.0
16 木	170	171	170	999	999	1,000	0.0	0.0	0.0
17 金		170	170		1,000	1,000		0.0	0.0
18 土	170	171	171	1,000	1,000	1,000	1.0	1.0	1.0
19 日	169	172	168	1,000	1,000	1,000	8.0	0.0	0.0
20 月	170	169	170	999	1,000	965	0.0	0.0	1.0
21 火	171	170	171	1,000	1,000	1,000	0.0	0.0	0.0
22 水	170	171	170	1,000	998	999	1.0	0.0	1.0
23 祝	168	170	171	1,001	1,000	1,000	0.0	0.0	0.0
24 金	173	168	169	1,000	1,000	1,000	0.0	0.0	1.0
25 土	170	170	168	999	1,008	980	0.0	0.0	0.0
26 日									
27 月	168	169	170	1,000	1,000	999	0.0	0.0	0.0
28 火	170	170	172	1,007	999	1,000	2.0	0.0	1.0
29 水	171	171	170	1,000	1,000	1,000	0.0	0.0	0.0
30 木	170	168	170	998	1,000	1,000	1.0	1.0	0.0