

【施設維持管理情報 令和6年】

1月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 火									
3 水									
4 木									
5 金	170	174	169	1,000	1,000	999	11.0	0.0	0.0
6 土	172	171	173	95	1,000	1,000	9.0	1.0	0.0
7 日	168	172	172	999	1,000	1,000	0.0	0.0	0.0
8 祝		174	171		998	1,000		13.0	10.0
9 火	171	172	171	1,000	1,000	899	1.0	0.0	0.0
10 水		173	172		1,000	1,000		1.0	0.0
11 木	166	171	172	1,000	1,003	1,001	0.0	0.0	0.0
12 金		172	173		1,002	1,000		7.0	1.0
13 土	174	172	172	1,000	1,000	999	1.0	0.0	0.0
14 日									
15 月	173	172	171	1,002	1,000	1,000	0.0	0.0	0.0
16 火	172	170	170	1,000	999	1,000	1.0	0.0	0.0
17 水	174	169	171	998	999	1,001	0.0	0.0	0.0
18 木	171	170	172	1,000	1,000	1,000	0.0	1.0	0.0
19 金	170	171	172	1,009	1,003	1,000	0.0	0.0	0.0
20 土	171	170	170	1,000	999	902	0.0	1.0	11.0
21 日				3					
22 月	168	169	172	1,000	1,000	1,009	1.0	0.0	0.0
23 火	172	170	170	1,010	1,002	997	3.0	0.0	0.0
24 水	170	171	170	999	1,000	996	2.0	0.0	1.0
25 木		169	170		999	1,000		0.0	0.0
26 金	172	173	170	1,002	1,003	999	0.0	0.0	0.0
27 土	174	171	172	1,000	1,000	1,000	0.0	0.0	0.0
28 日									
29 月	171	170	171	1,000	998	1,000	1.0	0.0	0.0
30 火	169	169	172	1,005	1,000	997	0.0	0.0	0.0
31 水	170	170	171	1,000	999	910	1.0	0.0	7.0