

【施設維持管理情報 令和6年】

2月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	169	171	172	1,000	1,000	1,001	1.0	0.0	0.0
2 金	170	172	170	999	1,001	1,000	0.0	0.0	0.0
3 土	172	171	173	1,000	1,000	915	0.0	1.0	15.0
4 日									
5 月	170	168	171	1,001	999	1,000	1.0	0.0	0.0
6 火	174	169	170	1,000	1,000	999	0.0	0.0	1.0
7 水		172	171		1,000	1,000		3.0	1.0
8 木	173	169	172	1,000	1,000	1,001	1.0	0.0	0.0
9 金	172	171	172	997	999	998	1.0	0.0	0.0
10 土	171	172	173	1,000	1,001	1,000	0.0	0.0	0.0
11 日									
12 月									
13 火	173	172	172	1,000	1,000	1,000	0.0	0.0	0.0
14 水	170	171	171	1,001	1,000	1,001	1.0	1.0	0.0
15 木	171	170	170	999	1,000	999	0.0	0.0	0.0
16 金	170	172	171	1,000	1,000	1,000	1.0	1.0	0.0
17 土	171	172	170	998	1,000	905	0.0	0.0	9.0
18 日									
19 月	170	172	172	1,000	1,000	900	0.0	1.0	0.0
20 火	171	171	172	999	999	1,000	1.0	0.0	0.0
21 水	170	172	171	1,000	1,000	1,000	0.0	0.0	0.0
22 木	174	171	172	1,000	1,001	1,000	1.0	1.0	0.0
23 金	170	168	171	1,000	1,000	1,000	0.0	0.0	0.0
24 土	173	172	174	999	1,000	970	0.0	0.0	2.0
25 日									
26 月	169	172	174	1,000	999	1,000	0.0	1.0	0.0
27 火	173	171	172	999	1,000	1,000	0.0	1.0	0.0
28 水	174	170	171	1,000	1,001	1,000	0.0	0.0	0.0
29 木	173	172	172	999	998	1,002	0.0	0.0	0.0