

【施設維持管理情報 令和6年】

3月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	168	168	171	1,000	999	1,001	1.0	0.0	0.0
2 土	170	172	170	1,000	1,000	990	7.0	0.0	0.0
3 日									
4 月	165	171	170	1,000	1,000	998	0.0	1.0	0.0
5 火	170	171	171	999	1,000	1,005	0.0	0.0	0.0
6 水	168	170	168	1,002	1,000	1,000	1.0	1.0	2.0
7 木	170	170	174	1,000	9,899	1,000	0.0	0.0	1.0
8 金	171	172	170	1,000	1,000	999	6.0	0.0	0.0
9 土	173	170	171	999	1,001	1,000	1.0	1.0	0.0
10 日		170	168		1,000	1,000		2.0	0.0
11 月	168	169	170	1,000	1,000	1,002	0.0	0.0	0.0
12 火	165	169	170	998	999	1,000	0.0	0.0	0.0
13 水	170	171	172	1,000	1,000	1,000	1.0	1.0	0.0
14 木	170	170	171	999	1,000	1,001	0.0	1.0	0.0
15 金	170	171	170	1,000	1,000	1,000	0.0	0.0	1.0
16 土	168	169	172	970	1,000	1,000	0.0	0.0	0.0
17 日									
18 月	171	170	171	1,000	999	999	9.0	0.0	1.0
19 火	170	170	170	1,000	1,000	1,000	0.0	0.0	0.0
20 祝	168	172	170	998	1,000	1,000	1.0	0.0	0.0
21 木	167	168	172	1,000	1,000	1,000	0.0	0.0	0.0
22 金	172	171	170	999	999	1,001	2.0	0.0	1.0
23 土	170	170	173	1,000	1,000	1,000	0.0	0.0	0.0
24 日									
25 月	171	168	170	1,000	1,000	1,000	0.0	1.0	0.0
26 火	170	170	171	999	1,000	1,000	0.0	0.0	0.0
27 水	169	171	172	1,000	1,000	998	0.0	1.0	0.0
28 木	170	170	169	1,000	1,000	1,000	0.0	0.0	2.0
29 金	171	169	170	999	999	999	0.0	0.0	0.0
30 土		169	170		1,000	1,000		7.0	0.0
31 日									