

【施設維持管理情報 令和6年】

6月

| 項目 時間 日 | 集塵器に流入する燃焼ガスの温度(°C) | | | 燃焼中の燃焼ガス温度(二次焼却炉内、°C) | | | 排ガス中の一酸化炭素濃度(PPM) | | |
|---------------|---------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|-------------------|-----------------|-----------------|
| | 10:00 ~13:00 | 13:00 ~16:00 | 16:00 ~19:00 | 10:00 ~13:00 | 13:00 ~16:00 | 16:00 ~19:00 | 10:00 ~13:00 | 13:00 ~16:00 | 16:00 ~19:00 |
| 1 土 | | | | | | | | | |
| 2 日 | | | | | | | | | |
| 3 月 | | | | | | | | | |
| 4 火 | | | | | | | | | |
| 5 水 | | | | | | | | | |
| 6 木 | | | | | | | | | |
| 7 金 | | | | | | | | | |
| 8 土 | | | | | | | | | |
| 9 日 | | | | | | | | | |
| 10 月 | | | | | | | | | |
| 11 火 | | | | | | | | | |
| 12 水 | | | | | | | | | |
| 13 木 | | | | | | | | | |
| 14 金 | | | | | | | | | |
| 15 土 | | | | | | | | | |
| 16 日 | | | | | | | | | |
| 17 月 | | | | | | | | | |
| 18 火 | | | | | | | | | |
| 19 水 | | | | | | | | | |
| 20 木 | | | | | | | | | |
| 21 金 | 174 | 172 | 173 | 1,000 | 1,000 | 999 | 5.0 | 0.0 | 1.0 |
| 22 土 | 172 | 173 | 170 | 999 | 1,001 | 1,000 | 2.0 | 0.0 | 0.0 |
| 23 日 | 169 | 171 | 171 | 1,000 | 1,000 | 950 | 0.0 | 0.0 | 10.0 |
| 24 月 | 174 | 173 | 173 | 1,000 | 999 | 1,000 | 1.0 | 0.0 | 1.0 |
| 25 火 | 172 | 172 | 172 | 1,000 | 1,000 | 999 | 0.0 | 1.0 | 0.0 |
| 26 水 | 172 | 173 | 171 | 998 | 1,001 | 1,000 | 1.0 | 0.0 | 0.0 |
| 27 木 | 173 | 174 | 172 | 999 | 1,000 | 1,000 | 1.0 | 1.0 | 0.0 |
| 28 金 | 171 | 172 | 173 | 1,000 | 1,000 | 1,000 | 2.0 | 2.0 | 0.0 |
| 29 土 | 173 | 171 | 174 | 997 | 998 | 999 | 0.0 | 0.0 | 1.0 |
| 30 日 | | | | | | | | | |
| | | | | | | | | | |