

【施設維持管理情報 令和6年】

9月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日									
2 月	170	173	174	999	1,000	1,000	1.0	0.0	0.0
3 火		172	173		1,000	1,000		0.0	0.0
4 水	170	171	174	1,000	1,000	1,000	0.0	0.0	0.0
5 木	168	170	172	990	1,000	999	1.0	1.0	0.0
6 金	170	174	173	1,000	1,000	1,001	0.0	0.0	0.0
7 土									
8 日	172	173	171	998	999	1,000	2.0	0.0	0.0
9 月	171	171	173	1,000	1,000	1,000	0.0	0.0	0.0
10 火	174	173	174	999	1,000	1,000	0.0	0.0	0.0
11 水		172	172		1,000	1,000		0.0	0.0
12 木	171	172	172	1,000	1,000	1,000	0.0	0.0	1.0
13 金	172	173	173	999	1,001	999	0.0	0.0	0.0
14 土									
15 日									
16 祝									
17 火	173	172	171	1,000	1,000	1,000	0.0	0.0	0.0
18 水		170	171		999	1,000		0.0	0.0
19 木	172	172	173	1,000	1,000	1,000	0.0	0.0	0.0
20 金									
21 土									
22 日	173	172	173	1,000	1,000	999	0.0	0.0	0.0
23 祝	172	171	173	1,000	1,000	1,000	0.0	0.0	0.0
24 火	169	170	173	999	1,000	1,000	1.0	0.0	3.0
25 水	172	173	174	1,000	1,000	999	3.0	0.0	0.0
26 木	171	170	172	990	1,000	1,000	0.0	0.0	0.0
27 金	170	171	173	1,000	1,000	1,000	0.0	0.0	0.0
28 土	168	173	171	957	1,000	1,000	5.0	0.0	0.0
29 日									
30 月	170	171	173	1,000	1,000	1,000	0.0	0.0	0.0