

【施設維持管理情報 令和6年】

11月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	172	170	173	1,000	1,000	1,000	1.0	0.0	0.0
2 土		173	172		1,000	999		0.0	0.0
3 日									
4 祝									
5 火	171	172	172	1,000	999	999	0.0	0.0	0.0
6 水	173	170	172	1,000	1,000	1,001	1.0	0.0	0.0
7 木		172	171		1,000	1,000		2.0	0.0
8 金	169	170	170	1,000	1,000	999	0.0	0.0	0.0
9 土	172	172	171	1,000	1,000	980	0.0	0.0	0.0
10 日									
11 月	171	170	172	1,000	1,000	1,000	1.0	0.0	0.0
12 火		169	170		1,000	999		0.0	0.0
13 水	172	173	174	999	1,000	1,000	10.0	0.0	0.0
14 木	173	174	173	1,000	1,000	1,000	0.0	0.0	0.0
15 金	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
16 土	172	171	170	1,000	999	975	0.0	1.0	0.0
17 日									
18 月	170	171	172	1,000	1,000	1,000	0.0	0.0	0.0
19 火		172	172		1,000	1,000		2.0	0.0
20 水	171	172	170	1,000	1,000	1,000	0.0	0.0	0.0
21 木		171	173		998	1,000		0.0	0.0
22 金	172	172	171	999	1,000	1,000	0.0	0.0	0.0
23 祝		168	170		1,000	1,000		10.0	0.0
24 日									
25 月	172	171	172	1,000	1,000	1,000	0.0	0.0	0.0
26 火		170	172		1,000	1,000		0.0	0.0
27 水	172	172	171	1,000	999	999	0.0	0.0	0.0
28 木		171	172		1,000	1,000		3.0	0.0
29 金	171	170	172	1,000	1,000	1,000	0.0	0.0	0.0
30 土									