

【施設維持管理情報 令和6年】

12月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日									
2 月	170	171	171	1,000	1,000	999	1.0	0.0	0.0
3 火		174	173		999	1,001		0.0	0.0
4 水	169	170	170	1,000	1,000	1,000	0.0	0.0	0.0
5 木	171	170	171	999	1,000	989	1.0	0.0	0.0
6 金	170	169	172	1,000	1,001	1,000	0.0	0.0	0.0
7 土	172	170	171	1,000	1,000	1,000	0.0	0.0	0.0
8 日									
9 月	171	170	171	999	1,002	1,000	1.0	1.0	0.0
10 火		172	172		1,000	1,000		0.0	0.0
11 水	170	171	171	1,000	1,000	1,000	0.0	0.0	0.0
12 木		172	170		1,000	1,000		1.0	0.0
13 金	172	170	169	1,000	1,000	1,000	0.0	0.0	0.0
14 土									
15 日									
16 月	171	170	170	999	999	1,000	0.0	1.0	0.0
17 火		172	171		1,000	1,000		3.0	1.0
18 水	172	171	172	1,000	1,000	1,000	8.0	0.0	0.0
19 木		170	171		1,000	1,002		1.0	0.0
20 金	171	170	171	1,000	999	998	0.0	0.0	0.0
21 土	171	172	171	1,000	998	1,000	0.0	0.0	0.0
22 日									
23 月	171	171	170	1,000	999	1,000	1.0	0.0	0.0
24 火		172	169		1,000	1,000		21.0	0.0
25 水	170	171	171	1,000	1,000	1,000	0.0	0.0	0.0
26 木	171	170	171	1,000	999	1,001	1.0	0.0	0.0
27 金	171	170	170	1,002	1,000	1,000	0.0	1.0	0.0
28 土		172	171		1,000	1,000		0.0	0.0
29 日									
30 月									
31 火									