【施設維持管理情報 令和7年】

1月

項目		集塵器に流入する燃焼ガ スの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
時間日		10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1	祝									
2	木									
3	金									
4	±									
5	日									
6	月									
7	火	170	170	170	1000	1000	1,000	11.0	0.0	0.0
8	水		172	171		999	1,000		2.0	0.0
9	木	169	171	170	1000	1001	1,000	0.0	0.0	0.0
10	金	170	172	171	1000	1000	1,000	0.0	0.0	0.0
11	±									
12	日									
13	祝	171	170	172	999	1000	1,001	8.0	0.0	1.0
14	火		173	171		1000	1,000		0.0	0.0
15	水	170	172	171	1000	1000	1,000	0.0	0.0	0.0
16	木	171	170	171	1000	1001	999	0.0	0.0	0.0
17	金	170	171	170	1000	1000	1,000	1.0	1.0	0.0
18	±	171	171	172	1000	999	980	2.0	0.0	0.0
19	日									
20	月	170	171	170	1000	1000	1,000	0.0	0.0	0.0
21	火		172	170		1000	1,000		0.0	0.0
22	水	169	170	169	1000	1000	999	1.0	0.0	0.0
23	木	171	169	170	999	1001	1,000	0.0	0.0	0.0
24	金		170	171		1000	1,000		8.0	0.0
25	±	174	171	170	1000	999	900	0.0	0.0	0.0
26	日									
27	月	171	170	171	1000	1000	1,000	0.0	0.0	0.0
28	火		167	170		1000	1,000		1.0	0.0
29	水	170	171	170	1000	1000	999	0.0	0.0	0.0
30	木		169	171		999	1,002		5.0	0.0
31	金	170	169	170	1000	1000	1,000	0.0	0.0	0.0

有限会社 栄晃