

【施設維持管理情報 令和7年】

5月

| 項目 時間 日 | 集塵器に流入する燃焼ガスの温度(°C) | | | 燃焼中の燃焼ガス温度(二次焼却炉内、°C) | | | 排ガス中の一酸化炭素濃度(PPM) | | |
|---------------|---------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|-------------------|-----------------|-----------------|
| | 10:00 ~13:00 | 13:00 ~16:00 | 16:00 ~19:00 | 10:00 ~13:00 | 13:00 ~16:00 | 16:00 ~19:00 | 10:00 ~13:00 | 13:00 ~16:00 | 16:00 ~19:00 |
| 1 木 | | 171 | 172 | | 1,000 | 1,000 | | 11.0 | 0.0 |
| 2 金 | 172 | 170 | 171 | 999 | 1,000 | 1,000 | 8.0 | 0.0 | 0.0 |
| 3 土 | | | | | | | | | |
| 4 日 | | | | | | | | | |
| 5 祝 | | | | | | | | | |
| 6 祝 | | | | | | | | | |
| 7 水 | 171 | 172 | 172 | 1,000 | 999 | 1,001 | 1.0 | 0.0 | 0.0 |
| 8 木 | | 173 | 172 | | 1,000 | 1,000 | | 0.0 | 0.0 |
| 9 金 | 174 | 173 | 172 | 1,000 | 1,000 | 1,000 | 13.0 | 0.0 | 0.0 |
| 10 土 | 171 | 172 | 171 | 999 | 1,000 | 989 | 8.0 | 0.0 | 0.0 |
| 11 日 | | | | | | | | | |
| 12 月 | 170 | 171 | 171 | 1,000 | 1,000 | 1,000 | 0.0 | 0.0 | 0.0 |
| 13 火 | | 172 | 171 | | 1,000 | 1,000 | | 1.0 | 0.0 |
| 14 水 | | | | | | | | | |
| 15 木 | | | | | | | | | |
| 16 金 | | | | | | | | | |
| 17 土 | | | | | | | | | |
| 18 日 | | | | | | | | | |
| 19 月 | | | | | | | | | |
| 20 火 | 171 | 170 | 174 | 1,000 | 1,000 | 1,000 | 0.0 | 0.0 | 0.0 |
| 21 水 | 171 | 172 | 172 | 1,000 | 1,000 | 1,000 | 3.0 | 0.0 | 0.0 |
| 22 木 | | 173 | 172 | | 999 | 1,000 | | 0.0 | 0.0 |
| 23 金 | 169 | 171 | 171 | 1,000 | 1,000 | 1,000 | 10.0 | 1.0 | 0.0 |
| 24 土 | 170 | 171 | 172 | 1,000 | 999 | 1,000 | 0.0 | 0.0 | 0.0 |
| 25 日 | | | | | | | | | |
| 26 月 | 172 | 171 | 172 | 1,000 | 1,000 | 999 | 5.0 | 0.0 | 0.0 |
| 27 火 | | 172 | 173 | | 1,000 | 1,000 | | 0.0 | 0.0 |
| 28 水 | 171 | 172 | 172 | 1,000 | 1,000 | 1,001 | 3.0 | 1.0 | 0.0 |
| 29 木 | | 171 | 172 | | 999 | 1,000 | | 0.0 | 0.0 |
| 30 金 | 171 | 170 | 172 | 1,000 | 1,000 | 1,000 | 12.0 | 0.0 | 0.0 |
| 31 土 | 172 | 171 | 171 | 999 | 1,000 | 1,000 | 0.0 | 0.0 | 0.0 |